

## PHARMA DEVILS QUALITY ASSURANCE DEPARTMENT

STANDARD OPERATING PROCEDURE	
SOP No.:	
<b>Effective Date:</b>	
<b>Review Date:</b>	
Page No.:	

#### **OBJECTIVE**

To lay down a procedure to describe the steps to be followed for using Purified water.

#### **SCOPE**

This SOP is applicable for usage of Purified water.

#### RESPONSIBILITY

Concerned staff

#### **ACCOUNTABILITY**

Department Head

#### **REFERENCES**

In-House

#### **ATTACHMENTS**

Nil

#### **PROCEDURE**

- 1.0 For usage of Purified water, open the valve of user point at maximum flow and allow the water to run for about one minute before taking it for use.
- 2.0 In the locations where hosepipes are connected to user point, use water from the end of hosepipe and allow the water to run for about one minute before taking it for usage.
- 3.0 Connect the hosepipe before usage and disconnect after operation.
- 4.0 Use separate hosepipes for process water and purified water.
- 5.0 Drain the hosepipe and dry after the usage.
- 6.0 Close the both ends with Aluminum foil and preserve until next use.



# PHARMA DEVILS QUALITY ASSURANCE DEPARTMENT

STANDARD OPERATING PROCEDURE	
<b>Department:</b> Quality Assurance	SOP No.:
Title: Usage of Purified Water	Effective Date:
Supersedes: Nil	Review Date:
Issue Date:	Page No.:

### 7.0 **ABBREVIATION**

SOP : Standard Operating Procedure

QA : Quality Assurance

CC No. Change Control number