



**PRE RISK ASSESSEMENT FOR VIBRO SIFTER**

**RISK ASSESSMENT  
REPORT BY FMEA**

<b>Product/System/Equipment</b>	<b>VIBRO SIFTER (12", 30" &amp; 48")</b>
<b>Risk Assessment Report No.</b>	
<b>Report Date</b>	



## PRE RISK ASSESSEMENT FOR VIBRO SIFTER

### TABLE OF CONTENTS

S.No.	Description	Page No.
1.0	Introduction	4
2.0	Objective	4
3.0	Scope	4
4.0	Risk Assessment Approach	4
5.0	Responsibility	4
6.0	Reference Documents	5
7.0	Risk Ranking Parameters	5
8.0	Acceptance Criteria for risk assessment by FMEA	7
9.0	Risk assessment as per FMEA	8
9.1	Review of Risk assessment as per FMEA after action taken.	12
10.0	Risk Control Measures	13
11.0	Summary and Conclusion Report for Risk Assessment	14
12.0	Final Report Approval	15



**PRE RISK ASSESSEMENT FOR VIBRO SIFTER**

**DOCUMENT APPROVAL:**

This risk analysis study for the preapproval of report by following:

Responsibility	Department	Name	Signature	Date
<b>Prepared by</b>	Quality Assurance			
	Production			
<b>Reviewed by</b>	Quality control			
	Engineering			
	Store			
	Quality Assurance			
	<b>Approved by</b>	Head-QA		



## **PRE RISK ASSESSEMENT FOR VIBRO SIFTER**

### **1.0 Introduction**

The “VIBRO SIFTER” is intended for uniformly grading of materials through the rotatory or longitudinal movements used in the conventional type of sieving machine both in terms of output .Material finer than the screen mesh passes through the screen and is collected in the bottom hopper and finally discharges through the port of hopper with assurance of product safety. Coarse material is retained on the top of screen.

### **2.0 Objective**

Objective of this report is to assess the risk associated with the equipment VIBRO SIFTER in pre assessment in the manufacturing facility of Cepha Block of ....., in line with the guidance of the Risk Management manual of ..... and ICH Q9.

### **3.0 Scope**

The scope of this document is limited to the design, installation, operation, performance and safety of equipment “VIBRO SIFTER” system and define its failure mode at pre assessment in the manufacturing facility of Cepha Block at .....

### **4.0 Risk assessment approach**

Risk assessment is carried out as per FMEA (Failure mode, effects analysis) method.

### **5.0 Responsibility**

Quality Assurance  
Engineering  
Production  
Quality Control  
Store

### **6.0 Reference Documents**

1. ICH Q9-Quality Risk Management
2. ....guidance on Risk assessment.



## PRE RISK ASSESSEMENT FOR VIBRO SIFTER

### Background

..... is intended to start manufacturing of solid oral facility at ..... Risk assessment is a part of corporate quality assurance. Pre Quality Risk assessment of "VIBRO SIFTER" is done to check the system is capable of providing quality product throughout the life cycle of the drug product.

### 7.0 RISK RANKING PARAMETERS

#### 7.1 Rating parameters for Severity

Effect	Scale	Description
No effect	1	No effect on output
Very slight	2	Customer not annoyed
Slight	3	Slight
Minor	4	Minor effect on performance
Moderate	5	Moderate effect on performance
Significant	6	Partial failure but operable
Major	7	Product performance severely affected, but some operability and safe
Extreme	8	Very dissatisfied, product inoperable but safe
Serious	9	Potentially hazardous effect, time-dependent failure
Hazardous	10	Hazardous effect, safety related sudden failure

#### 7.2 Rating parameters for Occurrence

Occurrence	Scale	Description
Almost never	1	Failure unlikely; history shows no failures
Remote	2	Rare number of historical failure
Very Slight	3	Very few failures likely
Slight	4	Few failures likely
Low	5	Occasional number of failures likely
Medium	6	Medium number of failures likely
Moderately High	7	Moderately high number of failures likely



## PRE RISK ASSESSEMENT FOR VIBRO SIFTER

Occurrence	Scale	Description
High	8	High number of failures likely
Very High	9	Very high number of failures likely
Almost certain	10	Failure almost certain

### 7.3 Rating parameters for Detection control

Detection	Scale	Description
Almost certain	1	Proven detection methods with high reliability
Very High	2	Proven detection methods available
High	3	Detection tools have high chance of detecting methods
Moderately High	4	Almost certain not to detect failure
Medium	5	Detection tools have moderate chance of detecting defect
Low	6	Detection tools have a low chance of detecting failure
Slight	7	Detection tools may not detect failure
Very Slight	8	Detection tools will probably not detect failure
Remote	9	Detection tools most likely will not detect failure
Impossible	10	Failure not detected

**Note:** Individual contributory factor for each potential failure mode shall be rated. Other scale parameters may also be selected based on the process.

### 8.0 ACCEPTANCE CRITERIA FOR RISK ASSESSMENT BY FMEA

Acceptance criteria for FMEA are as follows:

S.No.	RPN Rating	RPN Category	Action Status
1.	$\geq 76$	Critical	CAPA Required
2.	51 to 75	Major	CAPA Required
3.	26 to 50	Moderate	CAPA Required
4.	Up to 25	Minor	Not applicable



**PRE RISK ASSESSEMENT FOR VIBRO SIFTER**

**9.0 PRE-RISK ASSESSMENT AS PER FMEA:**

Name of facility/Utility/Equipment/Process/Operation: VIBRO SIFTER

S.No.	Potential Failure Mode	Potential effect (s) of failure	Severity (S)	Potential cause/ Mechanism of failure	Occurrence (O)	Current Control	Detection (D)	RPN (S x O x D)	Recommended action	Responsibility and TCD	Action Results				
											Action taken	Severity	Occurrence	Detection	New RPN
1	Required Area (floor, Temperature, RH, Differential pressure) not proper for the Vibrosifter.	Equipment may not function as desired.	6	No or less clarity of the product requirement and machine functionality.	3	Approved layout is in place with dimensions & required environmental condition	3	54	Care has to be taken during Area Qualification	Engineering, QA, Production					
2	Required parameter not defined in URS / URS not proper for system	Systems not receive suitable for proper output of quality with all parameter as per specification. Affect the product quality.	4	No or less clarity of the product requirement and machine functionality.	3	Preparation of URS before procurement of equipment is in place with all pre-specified parameter.	2	24	Current control measures are adequate	NA	NA	NA	NA	NA	NA



# PHARMA DEVILS

QUALITY ASSURANCE DEPARTMENT

## PRE RISK ASSESSEMENT FOR VIBRO SIFTER

S.No.	Potential Failure Mode	Potential effect (s) of failure	Severity (S)	Potential cause/ Mechanism of failure	Occurrence (O)	Current Control	Detection (D)	RPN (S x O x D)	Recommended action	Responsibility and TCD	Action Results				
											Action taken	Severity	Occurrence	Detection	New RPN
3	Required utilities (electricity, purified water, compressed air) are not available	Machine will not function as expected.	7	No or less clarity of the product requirement and machine functionality with respect to utility requirement.	2	URS is in place for system with all predefined requirement of utility like water, electricity.	1	14	Current control measures are adequate	NA	NA	NA	NA	NA	NA
4	Wrong machine selection in terms of Dimension, capacity and output.	Installation will be affected if dimension is not considered. Output will also get affected if capacity is not considered.	6	No or less clarity of the machine.	2	URS is in place for dimension , capacity and rated output of the of the Vibrosifter	1	12	Current control measures are adequate	NA	NA	NA	NA	NA	NA
5	MOC and machine contact parts ,Seals & gaskets not meeting GMP requirement	Not meeting GMP requirements and product get affected.	7	No or less clarity of the machine contact part and MOC.	3	URS is in place for MOC ( contact part should be of SS316 or 316L and non contact parts will be of SS304 and machine contact parts to fulfill GMP requirements. Gasket used shall be of food grade.	1	21	Current control measures are adequate	NA	NA	NA	NA	NA	NA





# PHARMA DEVILS

QUALITY ASSURANCE DEPARTMENT

## PRE RISK ASSESSEMENT FOR VIBRO SIFTER

S.No.	Potential Failure Mode	Potential effect (s) of failure	Severity (S)	Potential cause/ Mechanism of failure	Occurrence (O)	Current Control	Detection (D)	RPN (S x O x D)	Recommended action	Responsibility and TCD	Action Results				
											Action taken	Severity	Occurrence	Detection	New RPN
6	Locking provision for castor wheel of sifter	Accident may happen.	10	No or less clarity about equipment safety measures.	2	Castor wheel with lock arrangement is defined in URS.	1	20	Current control measures are adequate	NA	NA	NA	NA	NA	NA
7	Equipment not received with the process safety measures.	Accident may happen.	10	No or less clarity about equipment safety measures.	2	Requirement of Safety measures like LID, discharge port, Earthing, Flame proof motor, is defined in URS.	1	20	Current control measures are adequate	NA	NA	NA	NA	NA	NA
8	Dust collector not provided to suck powder generated	Dusting and congestion occurs	6	No or less clarity about equipment safety measures.	2	Dust collector unit provided on area mentioned on the lay out.	1	12	Current control measures are adequate	NA	NA	NA	NA	NA	NA





**PRE RISK ASSESSEMENT FOR VIBRO SIFTER**

**Corrective Action:** *(an extra sheet can be used if space is insufficient)*

.....

.....

.....

.....

.....

.....

.....

.....

.....

.....

.....

**(Sign/Date)**



**PRE RISK ASSESSEMENT FOR VIBRO SIFTER**

**11.0 SUMMARY AND CONCLUSION REPORT FOR RISK ASSESSMENT**

**Summary:** .....

.....  
.....  
.....  
.....  
.....  
.....  
.....  
.....  
.....

**Conclusion:**

.....  
.....  
.....  
.....  
.....  
.....  
.....  
.....  
.....



## PRE RISK ASSESSEMENT FOR VIBRO SIFTER

### 12.0 FINAL REPORT APPROVAL:

The final report shall be signed after identifying all the risks and critical control parameters. All the reports or documents have been attached to the respective report (if applicable).

Signature in the block below indicates that all the control measures taken are documented and have been reviewed and found to be acceptable.

Department	Name	Designation	Signature	Date
Quality assurance				
Production				
Quality control				
Engineering				
Store				
Head-QA				