



**PHARMA DEVILS**  
QUALITY ASSURANCE DEPARTMENT

**RISK ASSESSMENT FOR COMPRESSED AIR SYSTEM**

**Risk Assessment Document  
For  
Compressed Air System**



## **Table of Contents**

<b>1</b>	<b>Introduction .....</b>	<b>3</b>
<b>2</b>	<b>Aim of Risk Assessment .....</b>	<b>3</b>
<b>3</b>	<b>Reference Documents/ Drawings .....</b>	<b>3</b>
<b>4</b>	<b>Equipment/ System Description .....</b>	<b>3</b>
<b>5</b>	<b>Participants .....</b>	<b>4</b>
<b>6</b>	<b>Risk Management Process .....</b>	<b>4</b>
<b>6.1</b>	<b>Identifying GMP risk.....</b>	<b>5</b>
<b>6.2</b>	<b>Risk Analysis &amp; Evaluation .....</b>	<b>6</b>
<b>7</b>	<b>Risk Assessment .....</b>	<b>7</b>
<b>8</b>	<b>Summary &amp; Conclusion .....</b>	<b>24</b>
<b>9</b>	<b>Abbreviations .....</b>	<b>24</b>
<b>10</b>	<b>Revision History.....</b>	<b>24</b>



## RISK ASSESSMENT FOR COMPRESSED AIR SYSTEM

### 1 Introduction

According to the definition, given in Annex 15 to the EU-GMP-Guide, a Risk Assessment is a method to assess and characterize the critical parameters in the functionality of an equipment or process. Therefore, risk assessment is a key element in the qualification and validation approach.

In the project context, risk assessment for the equipment is performed as basic GMP/EHS-Risk Assessment, which shall help to identify important GMP/ EHS-requirements.

### 2 Aim of Risk Assessment

At the very basic stage of design the Risk Assessment is carried out to verify that all features are taken into consideration to avoid the risk of failure of critical GMP and EHS parameter in the equipment.

During study, all GMP, EHS and operational parameters will be identified and assessed for the risk, appropriate mitigation will be proposed and verification point will be identified and defined.

The Risk Assessment report is produced to provide the documented evidence that design concepts or requirement are complete in considering all GMP, EHS and operational risks.

### 3 Reference Documents/ Drawings

S.No.	Document Title	Document Number
1.	Validation master plan	

### 4 Equipment/ System Description

This risk assessment is conducted for a Compressed Air System, which shall consist of the following main components:

- Air Compressor
- Cooling Unit
- Desiccant type heatless Dryer
- Receiver
- Compressed air distribution system
- End point filter cartridges (In manufacturing, filtration, washing, filling & sealing areas)

The Compressed Air System for this project has been designed for obtaining clean compressed air to be used for:

- Process aeration
- Pneumatic operation (valves, doors etc.)

Most of the possible risk concerning the handling/ operation of the Compressed Air System has been considered in this RA document.



**RISK ASSESSMENT FOR COMPRESSED AIR SYSTEM**

**5 Participants**

Name	Designation/ Department	Signature/ Date

**6 Risk Management Process**

A typical Risk management process consists of following steps:

- Risk Assessment:
  - Risk Identification
  - Risk Analysis
  - Risk Evaluation
- Risk Control
  - Risk Reduction
  - Risk Acceptance
- Result of Risk management processes
- Risk Review
- Risk Assessment consists of the identification of hazards and the analysis and evaluation of risks associated with exposure to those hazards.  
Risk identification is a systematic use of information to identify hazards referring to the risk question or problem description.  
Risk analysis is the estimation of the risk associated with the identified hazards. It is the qualitative or quantitative process of linking the likelihood of occurrence and severity of harm.  
  
Risk evaluation compares the identified and analyzed risk against given risk criteria. Risk evaluation considers the strength of evidence for all three of the fundamental questions.  
The output of a risk assessment is either a quantitative estimate of risk or a qualitative description of range of risk. In case of qualitative description the risk is expressed using descriptors such as “high”, “medium” or “low”.
- Risk control includes decision making to reduce and/ or accept risks. The purpose of risk control is to reduce the risk to an acceptable level. The amount of effort used of risk control should be proportional to the significance of the risk.  
Risk reduction focuses on processes for mitigation or avoidance of quality risk when it exceeds a specified (acceptable) level. Risk reduction might include actions taken to mitigate the severity and probability of harm.  
Risk acceptance is a decision to accept risk. Risk acceptance can be a formal decision to accept the residual risk or it can be a passive decision in which residual risks are not specified.
- The output/ result of the quality risk management process should be appropriately communicated and documented.



## RISK ASSESSMENT FOR COMPRESSED AIR SYSTEM

- Risk management should be an ongoing part of the quality management process. A mechanism to review or monitor events should be implemented.
- The output/ results of the risk management process should be reviewed to take into account new knowledge and experience.

This document applies the risk management principles to identify the risks associated with the design, Construction and operational features of the proposed sterile formulation facility.

The objectives of this risk assessment are to:

- Review the design around a structured methodology
- Identify the failure modes and associated risks
- Check if the proposed control measures are adequate
- Identify recommendations to obtain a more acceptable risk level if required

### 6.1 Identifying GMP risk

Identification of Risk associated with the equipment, is generally based on prior experience and the concerns of the participants of risk assessment document.

The risks identified are categorized as “GMP risk” or “Non-GMP risk”.

GMP is defined as “the practices which ensures that products are consistently produced and controlled to the quality standards appropriate to their intended use and as required by the marketing authorization.”

Thus, GMP covers all aspects of the manufacturing process: defined manufacturing process; validated critical manufacturing steps; suitable premises, storage, transport; qualified and trained production and quality control personnel; adequate laboratory facilities; approved written procedures and instructions; records to show all steps of defined procedures have been taken; full traceability of a product through batch records and distribution records; and systems for recall and investigation of complaints.

Thus those risks which might have a direct or indirect impact on the quality of the product are classified as “GMP risk”. Also, those risks which might result in regulatory guidelines non-compliance are also classified as “GMP risk”.

For example: The Hygiene level of the manufacturing areas has a direct impact on the quality of the Product. Thus, it is classified as GMP risk.

The “Non GMP” risks include risks related to EHS, operational and other non-critical hazards.

Following types of risks are mainly identified during risk assessment process:

- Risk related to hygiene level of the manufacturing and supporting areas
- Risks related to appropriate utilities and their control (eg. power source, compressed air etc.)
- Risks related to calibration/ preventive maintenance
- Risks related to protection of the environment and health & safety of personnel.
- Risks related to cleaning & sterilization
- Risks related to unidirectional flow of the material
- Risks related to cross contamination of the products
- Risks related to entry and exit of personnel and material.
- Risks related to all the environment features of the manufacturing areas.
- Risks related to requirement of particular rooms for different activities.



**RISK ASSESSMENT FOR COMPRESSED AIR SYSTEM**

- Risks related to environment health and safety of personnel.

**6.2 RISK ANALYSIS & EVALUATION**

The risk analysis is performed using a qualitative basis of approach.

Qualitative analysis uses word form or descriptive scales to describe the magnitude of potential consequences/ impact and the likelihood that those consequences will occur.

The qualitative measures of likelihood includes descriptors like “Unlikely”, “Possible” and “Likely”, whereas the qualitative measures of consequence/ impact includes descriptors like “Minor”, “Moderate” and “Major”.

**Qualitative measures of likelihood**

Level	Descriptor	Example detail description
1	Unlikely	May occur at some time
2	Possible	Might occur at some time
3	Likely	Will probably occur in most circumstances

**Qualitative measures of consequence/ impact**

Level	Descriptor	Example detail description
1	Minor	<ul style="list-style-type: none"> <li>• No impact on the product quality or outcome of the equipment.</li> <li>• Features required for easing equipment operation.</li> </ul>
2	Moderate	<ul style="list-style-type: none"> <li>• No direct impact on product quality/ outcome of equipment. However may indirectly affect the product quality.</li> <li>• Minor effect on personnel health</li> <li>• Used in the initial stage of operation, however it may affect the final output but those are not used for final release of output.</li> <li>• Effect on environment such as clean room.</li> </ul>
3	Major	<ul style="list-style-type: none"> <li>• Features having direct impact on product quality/ outcome of equipment like contact parts MOC, Surface finish, Control system, Process air quality etc.</li> <li>• Failure could lead to regulatory non-compliance.</li> <li>• Loss/ damage to equipment or its critical sub-components</li> <li>• Critical instruments not calibrated or not of desired range or accuracy.</li> <li>• Proper supporting documentation not provided.</li> <li>• Major effect on personnel health</li> </ul>

Based on the above parameters of likelihood and consequence a qualitative risk analysis matrix is prepared to identify the overall Level of Risk, as mentioned in table below.



**RISK ASSESSMENT FOR COMPRESSED AIR SYSTEM**

**Qualitative risk analysis matrix – level of risk**

Likelihood	Consequences/ Impact		
	1 – Minor	2 – Moderate	3 – Major
<b>1 (Unlikely)</b>	Low	Medium	High
<b>2 (Possible)</b>	Low	Medium	High
<b>3 (Likely)</b>	Medium	High	High

The final Risk level shall thus be described using descriptors such as “Low”, “Medium” & “High”, where each descriptor implies the following meaning:

**Low** – Risk can be accepted or ignored. These do not affect the final quality of the equipment/ system and it can be managed by routine procedures and are unlikely to need specific application of resources.

**Medium** – Risk required ongoing monitoring and review, to ensure level of risk does not increase. Otherwise managed by routine procedures.

**High** – Action plans must be developed, with clear assignments of individual responsibilities and timeframes.

**7 Risk Assessment**

In the following section a table is produced for the risk assessment. The significance or instruction for each column is described in the following paragraph.

- Column 1 : **Serial number** of the Risk assessment item
- Column 2 : **Process step/ Component:** Identify the process step or component associated with the risk.
- Column 3 : **Risks:** Identify the type of risk associated with the process or component
- Column 4 : Verify that whether risk have **GMP impact** in terms of Yes/ No.
- Column 5 : **Justification:** Provide justification for declaring both Yes/ No for GMP impact in column 4.
- Column 6 : For the risk **other than of GMP impact**, write that what is/ are the type of risks e.g. EHS, operational, etc.
- Column 7 : **Justification:** Provide justification for considering the risk.
- Column 8 : **Risk level:** Determine the risk level as High, Medium or low based on the impact.
- Column 9 : **Risk Control:** It is further divided into the following three sections:
- Column 9a : **Mitigation Method:** Write the risk mitigation strategy as considered in the design.



# PHARMA DEVILS

QUALITY ASSURANCE DEPARTMENT

## RISK ASSESSMENT FOR COMPRESSED AIR SYSTEM

- Column 9b : **Residual risk level:** After the risk mitigation what is the residual risk level, whether it is Acceptable, Low or Medium.
- Column 9c : **Test document:** Write the test point where the risk mitigation strategy will be verified.
- Column 10 : **Status of RA:** Mention the status of the Risk assessment point i.e. whether it is 'Closed" or "Open", after the execution/ approval of the Test document.





# PHARMA DEVILS

QUALITY ASSURANCE DEPARTMENT

## RISK ASSESSMENT FOR COMPRESSED AIR SYSTEM

S.No. (1)	Process steps/ component (2)	Risk (3)	GMP Risk Yes/ No (4)	Justification (5)	Other Risk type (6)	Justification (7)	Risk Level (8)	Risk Control (9)			Status of RA (10)
								Mitigation Method (9a)	Residual risk level (9b)	Test Document (9c)	
<b>Supply Air</b>											
1.	Supply air	Quality of the supply air is not good, contaminated with vapours.	Yes	Vapours will pass through the compressor and contaminate the products.	No	NA	High	The suction port of the Compressor will be installed in inverted position to avoid direct entry of vapours.	Acceptable	IQ & OQ	
2.	Supply air	Insects and heavy dust particles in the air.	No	As pre filters and fine filters are there, it will arrest the same.	Operational	Choking of the pre-filter leads to easy damage of filters.	Medium	Wire mesh will be fixed on the suction port followed by coarse filters to control these particles.	Acceptable	IQ & OQ	
3.	Supply air	Source supply air is having high humidity.	Yes	Final air quality cannot be maintained	No	NA	High	<ul style="list-style-type: none"> <li>The compressed air system should have inbuilt moisture Separator or other mechanism to handle the high humidity.</li> <li>Air compressor should have an air dryer at the discharge line for removing moisture.</li> </ul>	Acceptable	IQ & OQ	
4.	Compressor	The compressor is not meeting the required pressure	Yes	Insufficient performance of connected systems	No	NA	High	<ul style="list-style-type: none"> <li>Air compressor shall be single/double stage oil free type or other suitable design to provide the required output.</li> <li>Motor shall be design to meet the plant capacity.</li> <li>Air compressor shall have provision to measure the pressure.</li> </ul>	Acceptable	IQ & OQ	



# PHARMA DEVILS

QUALITY ASSURANCE DEPARTMENT

## RISK ASSESSMENT FOR COMPRESSED AIR SYSTEM

S.No. (1)	Process steps/ component (2)	Risk (3)	GMP Risk Yes/ No (4)	Justification (5)	Other Risk type (6)	Justification (7)	Risk Level (8)	Risk Control (9)			Status of RA (10)
								Mitigation Method (9a)	Residual risk level (9b)	Test Document (9c)	
5.	Compressor	Compressed air supply gets stopped during maintenance.	Yes	Routine production activity may get disturbed.	Operational	Routine maintenance schedule may get delayed due to continuous production operation.	High	Stand by compressor will be considered for trouble free continuous operation.	Acceptable	IQ & OQ	
<b>Coolant</b>											
6.	Coolant	Inadequate coolant	Yes	Temperature of the air will be high hence also affect the moisture content	No	NA	High	<ul style="list-style-type: none"> <li>Cooling water shall be used as coolant in both inter cooler and after cooler.</li> <li>Limit and pressure switches to ensure the availability of water flow.</li> <li>Cooling water inlet and outlet temperature should be monitored and regulated.</li> </ul>	Acceptable	IQ & OQ	
<b>Intercooler</b>											
7.	Inter cooler	Air output temperature is high	No	NA	Operational	The downstream system should be compatible with that temperature	Medium	The inter cooler to be properly designed to take the load.	Acceptable	IQ & OQ	
8.	Inter cooler	Material of construction of the exchanger is not compatible.	No	NA	Operational	As the moisture is high, it can leads to corrosion of the exchanger.	Medium	Copper tube for air passing is recommended to avoid the same.	Acceptable	IQ	
9.	Inter cooler	Cooling media is not available	No	NA	Operational	Improper heat transfer leads to improper function of the downstream system.	Medium	<ul style="list-style-type: none"> <li>Cooling water / Air can be used as a cooling media.</li> <li>Alarm system to be initiated with shut down the system if cooling water is not</li> </ul>	Acceptable	IQ & OQ	



# PHARMA DEVILS

QUALITY ASSURANCE DEPARTMENT

## RISK ASSESSMENT FOR COMPRESSED AIR SYSTEM

S.No. (1)	Process steps/ component (2)	Risk (3)	GMP Risk Yes/ No (4)	Justification (5)	Other Risk type (6)	Justification (7)	Risk Level (8)	Risk Control (9)			Status of RA (10)
								Mitigation Method (9a)	Residual risk level (9b)	Test Document (9c)	
								available.			
10.	Inter cooler	Scale formation in the shell side of the exchanger.	No	NA	Operational	Scale formation leads to improper heat transfer.	Medium	Soft water to be used for the same to avoid the scale formation.	Acceptable	IQ	
11.	Inter cooler	The air coming out of the intercooler has water droplets due to the cooling effect.	Yes	The moisture will be carried with the air.	Operational	The heavy moisture will increase the load on the Air drier.	Medium	Moisture separator will be considered after the inter cooler with auto drain valve to drain the moisture.	Acceptable	IQ & OQ	
12.	Inter cooler	Possibility of pressure built up in the intercooler.	No	NA	Operational/ EHS	Possibility is high due continuous supply of pressurized air.	High	<ul style="list-style-type: none"> <li>Safety relief valve will be provided on the inter cooler with set limit to handle the same.</li> <li>Pressure gauge will be provided to monitor of the intercooler.</li> </ul>	Acceptable	IQ & OQ	
<b>After Cooler</b>											
13.	After cooler	Air output temperature is high	No	NA	Operational	The downstream system should be compatible with that temperature	Medium	<ul style="list-style-type: none"> <li>The After cooler to be properly designed to take the load.</li> <li>Shell and tube type exchanger is advisable with copper tube for better heat transfer.</li> <li>Minimum pressure check valve shall be installed before after cooler</li> </ul>	Acceptable	IQ & OQ	



# PHARMA DEVILS

QUALITY ASSURANCE DEPARTMENT

## RISK ASSESSMENT FOR COMPRESSED AIR SYSTEM

S.No. (1)	Process steps/ component (2)	Risk (3)	GMP Risk Yes/ No (4)	Justification (5)	Other Risk type (6)	Justification (7)	Risk Level (8)	Risk Control (9)			Status of RA (10)
								Mitigation Method (9a)	Residual risk level (9b)	Test Document (9c)	
14.	After cooler	Material of construction of the heat exchanger is not compatible.	No	NA	Operational/ Financial	As the moisture is high, it can leads to corrosion of the heat exchanger.	Medium	Copper/aluminium tube for air passing is recommended to avoid the same.	Acceptable	IQ	
15.	After cooler	The air coming out of the After cooler has water droplets due to the cooling effect.	Yes	The moisture will be carrier with the air.	Operational	The heavy moisture will increase the load on the Air drier.	Medium	Moisture separator will be considered after the cooler with auto drain valve to drain the moisture.	Acceptable	IQ & OQ	
<b>Air Dryer</b>											
16.	Air dryer	Air humidity	Yes	Too high air humidity may lead to corrosion. Too high air humidity may lead to microbial growth and agglomerations of product	No	NA	High	<ul style="list-style-type: none"> <li>Dew point (<math>\leq -40^{\circ}\text{C}</math>) &amp; water content, class 2 according ISO 8573-1.</li> <li>Desiccant type or heatless air dryer should be recommended for the same.</li> </ul>	Acceptable	IQ & OQ	
17.	Air dryer	The production will be disturbed during the regeneration.	Yes	The down steam system will be disturbed	No	NA	High	The system shall be auto regenerated and for the operation two tower systems shall be considered when one under functioning the other will be get regenerated.	Acceptable	IQ & OQ	
<b>Air Quality</b>											
18.	Air Quality	Insufficient air Quality	Yes	Air quality must be suitable for the intended operation all the time	No	NA	Yes	<ul style="list-style-type: none"> <li>Air quality according to current EP, and USP and in-house requirement (particle size, - residuary oil, dew point &amp; water</li> </ul>	Acceptable	IQ, OQ & PQ	



# PHARMA DEVILS

QUALITY ASSURANCE DEPARTMENT

## RISK ASSESSMENT FOR COMPRESSED AIR SYSTEM

S.No. (1)	Process steps/ component (2)	Risk (3)	GMP Risk Yes/ No (4)	Justification (5)	Other Risk type (6)	Justification (7)	Risk Level (8)	Risk Control (9)			Status of RA (10)
								Mitigation Method (9a)	Residual risk level (9b)	Test Document (9c)	
								content, viable and nonviable count, Hydrocarbon content) <ul style="list-style-type: none"> <li>SOP: For Operation, Cleaning and preventive maintenance of system, filter, definition of life of filter units</li> </ul>			
19.	Air Quality	Pressure drop / variation / pressure stroke / pressure repulsion	Yes	Air quality must be suitable for the intended operation all the time	Operational / EHS	Cannot operate the system connected with it.	High	Air Receiver to be provided after Air dryer.	Acceptable	IQ	
<b>Air Receiver</b>											
20.	Air Receiver	The capacity of the receiver is not sufficient	No	It will not affect the quality of the air.	Operational	Insufficient to satisfy operational needs	High	Suitable capacity tank to be designed.	Acceptable	IQ	
21.	Air Receiver	The receiver will be over pressured	No	It will not affect the quality of the air.	Operational / EHS	Continuous running of compressor leads to pressure built up in the tank.	High	<ul style="list-style-type: none"> <li>The tank shall be designed with safety valve.</li> <li>The tank shall be designed with consideration of all safety aspects.</li> <li>Pressure gauge shall be provided on the receiver tank</li> </ul>	Acceptable	IQ & OQ	



# PHARMA DEVILS

QUALITY ASSURANCE DEPARTMENT

## RISK ASSESSMENT FOR COMPRESSED AIR SYSTEM

S.No. (1)	Process steps/ component (2)	Risk (3)	GMP Risk Yes/ No (4)	Justification (5)	Other Risk type (6)	Justification (7)	Risk Level (8)	Risk Control (9)			Status of RA (10)
								Mitigation Method (9a)	Residual risk level (9b)	Test Document (9c)	
22.	Air Receiver	Possibility of water collection in the Air Receiver	Yes	Will not meet the final quantity of air.	No	NA	Medium	Auto drain valve or manual drain valve shall be considered on the receiver tank. The blow down interval can be adjusted based on requirement.	Acceptable	IQ & OQ	
<b>Air Filter</b>											
23.	Air Filter	Particles from the receiver block the pipelines.	No	As final filter is there in the user point, it will not affect the quality of the air.	Operational	Pipelines will be blocked and leads to productivity loss.	Medium	5.0, micron 1.0 Micron followed by 0.1 Micron filter should be considered at the outlet of Air receiver so as to arrest the particles.	Acceptable	IQ	
<b>Distribution System</b>											
24.	Distribution piping.	High pressure than the desired limit	No	NA	EHS	High pressure may cause damage in piping system	Medium	Pressure switch, safety valves are considered in the distribution system addressing the same.	Acceptable	IQ	
25.	Distribution piping.	Pressure leakage may occur	Yes	May leads to pressure drop in supply line as well as low pressure will observed at user points	No	NA	High	Pressure leak test report of pipeline should be available.	Acceptable	IQ	



# PHARMA DEVILS

QUALITY ASSURANCE DEPARTMENT

## RISK ASSESSMENT FOR COMPRESSED AIR SYSTEM

S.No. (1)	Process steps/ component (2)	Risk (3)	GMP Risk Yes/ No (4)	Justification (5)	Other Risk type (6)	Justification (7)	Risk Level (8)	Risk Control (9)			Status of RA (10)
								Mitigation Method (9a)	Residual risk level (9b)	Test Document (9c)	
26.	MOC of pipe	MOC of the pipe is not compatible.	Yes	Corrosion and leads to particle shedding.	No	NA	Medium	PPR/ Aluminium /SS 316 or better pipes shall be considered to avoid the same based on the criticality for distribution of air manufacturing area (Product contact surfaces).	Acceptable	IQ	
27.	Distribution piping	Filters are not functioning properly.	Yes	Filter is intended as additional guard (particle from piping system)	No	NA	High	<ul style="list-style-type: none"> <li>Filter shall ensure specified air quality.</li> <li>Gaskets, seals and O-rings should be constructed of Food grade / non-toxic polymeric materials only.</li> <li>SOP: preventive maintenance, definition of filter change intervals</li> </ul>	Acceptable	IQ & SOP	
28.	Piping	Moisture / condensate in dead ends / dead legs	Yes	Forming of condensate is almost excluded due to dryness of air.  Piping shall be executed as loop (per level)	No	NA	Medium	Draining shall be possible at lowest point of loop	Acceptable	IQ	
29.	Piping	No sampling points are considered in the distribution points for testing.	Yes	It is GMP requirement to ensure the quality before using.	NO	NA	High	Sampling points will be considered in the piping routing layout and to be designed as per that.	Acceptable	IQ & OQ	
30.	Points of use	Possibility of particle flow from the pipe line to the user end/ System.	Yes	Contamination of products.	Operational	Particles may choke the inlet of critical system.	Medium	0.2 Micron filters will be placed on all critical user points to arrest the same.	Acceptable	IQ & OQ	



# PHARMA DEVILS

QUALITY ASSURANCE DEPARTMENT

## RISK ASSESSMENT FOR COMPRESSED AIR SYSTEM

S.No. (1)	Process steps/ component (2)	Risk (3)	GMP Risk Yes/ No (4)	Justification (5)	Other Risk type (6)	Justification (7)	Risk Level (8)	Risk Control (9)			Status of RA (10)
								Mitigation Method (9a)	Residual risk level (9b)	Test Document (9c)	
31.	Points of use	High pressure than the desired requirement for the system High pressure at user points.	No	NA	Operational	High pressure may damage the system.	High	Those critical system has inbuilt pressure regulation system to address the issue.	Acceptable	IQ	
32.	Points of use	Too many consumer units, pressure drop	Yes	Insufficient machine operation (control air)	No	NA	High	<ul style="list-style-type: none"> <li>The distribution System is connected to the plant system which comprises more than one compressors (redundancy)</li> <li>Pressure checking at all user points during qualification.</li> </ul>	Acceptable	IQ & OQ	
33.	Points of use	All the user points are not considered in the distribution piping.	Yes	Compressed air will not be available.	No	NA	High	Installation of piping with respect to the pipe routing of compressed air based on the user points considered.	Acceptable	IQ	
34.	Welding	Welding not proper	Yes	Corrosion may be possible particle émission	No	NA	High	<ul style="list-style-type: none"> <li>Welder reference certificates shall be available for orbital welding.</li> <li>Care shall be taken to maintain full alloying even in the outermost layers of the surface to reduce oxidation or heat tint.</li> <li>Least number of joints shall be considered during designing.</li> </ul>	Acceptable	IQ	

Operation





# PHARMA DEVILS

QUALITY ASSURANCE DEPARTMENT

## RISK ASSESSMENT FOR COMPRESSED AIR SYSTEM

S.No. (1)	Process steps/ component (2)	Risk (3)	GMP Risk Yes/ No (4)	Justification (5)	Other Risk type (6)	Justification (7)	Risk Level (8)	Risk Control (9)			Status of RA (10)
								Mitigation Method (9a)	Residual risk level (9b)	Test Document (9c)	
35.	Process compressed air	Quality relevant parameters are not controlled	Yes	Process compressed air must fulfil quality requirements	No	NA	High	System qualification	Acceptable	IQ & OQ	
36.	Process compressed air	System performance not sufficient	Yes	Influence on product quality possible, if sufficient amount of process air is not available	No	NA	High	System design to be adapted to fulfil the need	Acceptable	IQ & OQ	
<b>Maintenance</b>											
37.	Maintenance	Malfunctions due to worn parts	Yes	Basic GMP requirement	No	NA	High	<ul style="list-style-type: none"> <li>Machine shall be easy to maintain.</li> <li>Preventive maintenance procedure should be available</li> <li>The unit must contain necessary protection devices to ensure that the equipment &amp; the article remain in a safe condition.</li> </ul>	Acceptable	IQ & SOP	
<b>Safety</b>											
38.	Safety	No safety against high pressure, Hot surfaces, Rotating parts, Noise level etc.	No	NA	Operational/ / EHS	High pressure may leads to an accident	High	<ul style="list-style-type: none"> <li>Safety valve shall be provided.</li> <li>Warning stickers on all hot surfaces.</li> <li>Appropriate closure of all the rotating parts.</li> </ul>	Acceptable	IQ & OQ	



# PHARMA DEVILS

QUALITY ASSURANCE DEPARTMENT

## RISK ASSESSMENT FOR COMPRESSED AIR SYSTEM

S.No. (1)	Process steps/ component (2)	Risk (3)	GMP Risk Yes/ No (4)	Justification (5)	Other Risk type (6)	Justification (7)	Risk Level (8)	Risk Control (9)			Status of RA (10)
								Mitigation Method (9a)	Residual risk level (9b)	Test Document (9c)	
								<ul style="list-style-type: none"> <li>Noise level of the system shall be less than 80 db of 1m distance from the system.</li> </ul>			
39.	Safety	Proper pipe identification system not available.	No	NA	Operational	Improper identification leads to the mistake of operating of other utility instead of air.	High	Proper colour coding to be practised to avoid such mistakes.	Acceptable	IQ & SOP	
40.	Emergency stop	Instantaneous stopping of the machine not possible	No	Does not have any impact on quality of the product	EHS	Emergency stop function is required for equipment, personnel and product protection	High	Emergency stop with alarm to be installed on control panel.	Acceptable	IQ	
41.	Noise level	More noise is produced by the compressor during the operation.	No	Does not have any impact on quality of the product	EHS	High noise may cause deafness and anxiety	Medium	<ul style="list-style-type: none"> <li>Compressor should be provided with anti-vibration mountings to reduce vibration and noise.</li> <li>Noise level shall be below 80 db at a distance of 1 m from the equipment.</li> <li>Operator should bear ear plug.</li> </ul>	Acceptable	IQ & OQ	
<b>Measuring Instrument</b>											
42.	Measuring Instruments	Measuring Instruments not suitable	Yes	Improper measurements	No	NA	High	<ul style="list-style-type: none"> <li>Measuring Instruments must have a suitable measuring range.</li> <li>Operational range of</li> </ul>	Acceptable	IQ & OQ	



# PHARMA DEVILS

QUALITY ASSURANCE DEPARTMENT

## RISK ASSESSMENT FOR COMPRESSED AIR SYSTEM

S.No. (1)	Process steps/ component (2)	Risk (3)	GMP Risk Yes/ No (4)	Justification (5)	Other Risk type (6)	Justification (7)	Risk Level (8)	Risk Control (9)			Status of RA (10)
								Mitigation Method (9a)	Residual risk level (9b)	Test Document (9c)	
								Measuring Instruments > equipment working range.			
43.	Measuring instruments	Measuring instruments not calibrated	Yes	Non calibrated measuring instruments may lead to false information	No	NA	High	<ul style="list-style-type: none"> <li>Measuring Instruments must have appropriate accuracy.</li> <li>Measuring instruments should be calibrated (full loop calibration).</li> </ul>	Acceptable	IQ & OQ	
44.	GMP relevant measuring instruments	Instruments cannot be dismantled	Yes	Defective instruments must be dismantled for exchange and calibration	No	NA	High	<ul style="list-style-type: none"> <li>Mounting of instruments must give the possibility for dismantling and replacement</li> <li>Constructional solution: easy access for re-calibration activities shall be given.</li> </ul>	Acceptable	IQ	
<b>Cleaning</b>											
45.	Cleaning	Improper cleaning	Yes	Accumulation of particles leading to alteration in system performance as well as alteration in product quality	No	NA	High	Proper cleaning method has to be provisioned. All gaskets provided to avoid leakage should be amenable for easy removal & re- fixing for cleaning.	Acceptable	IQ & OQ	
46.	Cleaning	Difficulty in cleaning	Yes	Parts need to be disassembled for proper cleaning	No	NA	Medium	The design shall ensure adequate clean ability	Acceptable	IQ & OQ	
47.	Draining	Improper Drain ability or no Drain ability	Yes	Residual water may cause microbial growth & may increase humidity in	No	NA	High	<ul style="list-style-type: none"> <li>Drains shall be located at appropriate locations &amp; proper slope shall be provided in the drain tray.</li> </ul>	Acceptable	IQ	



# PHARMA DEVILS

QUALITY ASSURANCE DEPARTMENT

## RISK ASSESSMENT FOR COMPRESSED AIR SYSTEM

S.No. (1)	Process steps/ component (2)	Risk (3)	GMP Risk Yes/ No (4)	Justification (5)	Other Risk type (6)	Justification (7)	Risk Level (8)	Risk Control (9)			Status of RA (10)
								Mitigation Method (9a)	Residual risk level (9b)	Test Document (9c)	
				the rooms				<ul style="list-style-type: none"> <li>The pipe surface shall be buffed to the extend for easy cleaning operations internally and externally.</li> </ul>			
<b>Control System</b>											
48.	Man-machine Interface	Process / process status not visible for operating personnel	Yes	Operating personnel must have knowledge of the process status	No	NA	High	Machine shall be fitted with adequate display and clean room suitable key board for operation.	Acceptable	IQ	
49.	Man-machine Interface	Display language not identified.	Yes	Pre-requisite for the GMP compliant operation	No	NA	High	The language on the display of MMI should be English language only.	Acceptable	OQ	
50.	PLC / Control system	Malfunction	Yes	Correct function basic requirement for GMP-compliant operation	No	NA	High	<ul style="list-style-type: none"> <li>Supplier analysis (quality management system for software and control system hardware development)</li> <li>Input-output verification shall be performed.</li> <li>The system must contain all necessary protection devices to ensure that the equipment and article remain in safe condition.</li> </ul>	Acceptable	OQ	
51.	PLC/ Control System	Controlling of critical process parameters not possible	Yes	Basic GMP requirement	No	NA	High	PLC should be able to control critical process parameters	Acceptable	OQ	



# PHARMA DEVILS

QUALITY ASSURANCE DEPARTMENT

## RISK ASSESSMENT FOR COMPRESSED AIR SYSTEM

S.No. (1)	Process steps/ component (2)	Risk (3)	GMP Risk Yes/ No (4)	Justification (5)	Other Risk type (6)	Justification (7)	Risk Level (8)	Risk Control (9)			Status of RA (10)
								Mitigation Method (9a)	Residual risk level (9b)	Test Document (9c)	
52.	PLC/ Control System	Control system does not able to detect failures and generate alarms	Yes	Operating personnel will not be able to know the error occurred in the systems.	No	NA	High	<ul style="list-style-type: none"> <li>Failure of set parameters gets indicated as alarms and machine stops.</li> <li>Alarm list has to be defined.</li> </ul>	Acceptable	OQ	
53.	PLC / Control system	Parameters and their status not displayed	Yes	Operating personnel will not be able to know the required parameters and value hence may cause alteration in product quality as well as damage to machine.	No	NA	High	<ul style="list-style-type: none"> <li>Parameters and their status should remain displayed at each process stage.</li> <li>The flow of the process shall be provided with the help of arrows.</li> </ul>	Acceptable	OQ	
54.	PLC/Control Parameters settings	Parameter settings not identified universally	Yes	Basic GMP requirement	No	NA	High	Parameters settings should be in numeric only.	Acceptable	OQ	
55.	PLC/ Control System	Time measurement incorrect	Yes	Incorrect Process time leads to uncleared information	No	NA	High	<ul style="list-style-type: none"> <li>PLC clock verification</li> <li>SOP "calibration and maintenance"</li> <li>Time synchronization of system</li> </ul>	Acceptable	OQ/ SOP	
56.	Accessibility to PLC	No protection of PLC against manipulation & changes.	Yes	Basic GMP requirement.	No	NA	High	<ul style="list-style-type: none"> <li>Minimum 3 level password protections should be provided. <ul style="list-style-type: none"> <li>Level 1: for operator settable parameters.</li> <li>Level 2: for editing cycle parameters.</li> <li>Level 3: for admin/ engineering level setting.</li> </ul> </li> </ul>	Acceptable	OQ	



# PHARMA DEVILS

QUALITY ASSURANCE DEPARTMENT

## RISK ASSESSMENT FOR COMPRESSED AIR SYSTEM

S.No. (1)	Process steps/ component (2)	Risk (3)	GMP Risk Yes/ No (4)	Justification (5)	Other Risk type (6)	Justification (7)	Risk Level (8)	Risk Control (9)			Status of RA (10)
								Mitigation Method (9a)	Residual risk level (9b)	Test Document (9c)	
57.	Power	System will restart on its own during Power regain after failure.	No	NA	EHS	May end in accident due to unnoticed starting of the system.	High	<ul style="list-style-type: none"> <li>During power failure system will come safe to the shutdown mode.</li> <li>Restart of the system will be only through Human intervention.</li> </ul>	Acceptable	IQ & OQ	
58.	Power	Alteration in system performance	Yes	Disturbance of the conditions may lead to alteration in product quality	No	NA	High	On resume of power system will start normally.	Acceptable	OQ	
<b>Documentation</b>											
59.	User	Faulty operation & maintenance	Yes	SOPs are basic GMP-requirement	No	NA	High	<ul style="list-style-type: none"> <li>All end-users have to be trained on SOPs</li> <li>Training of SOPs has to be documented</li> <li>Training on the job of end users by vendor</li> <li>Training on operation, setting parameters, trouble shooting &amp; maintenance related activities.</li> </ul>	Acceptable	OQ & SOP	
60.	User	Operation SOP does not contain proper information and user may operate system	Yes	User may make a wrong decision.	No	NA	High	<ul style="list-style-type: none"> <li>System operation SOP must be reviewed with all aspects and approved.</li> <li>Vendor shall provide execution support to the user to complete all stages of the qualification report.</li> </ul>	Acceptable	OQ	
61.	User	Unauthorized person tries to start/stop the system	Yes	Untrained persons may damage the system or product quality may be affected	No	NA	High	<ul style="list-style-type: none"> <li>System should not start without password.</li> <li>Key-switch should be provided for system power up.</li> </ul>	Acceptable	IQ & OQ	



# PHARMA DEVILS

QUALITY ASSURANCE DEPARTMENT

## RISK ASSESSMENT FOR COMPRESSED AIR SYSTEM

S.No. (1)	Process steps/ component (2)	Risk (3)	GMP Risk Yes/ No (4)	Justification (5)	Other Risk type (6)	Justification (7)	Risk Level (8)	Risk Control (9)			Status of RA (10)
								Mitigation Method (9a)	Residual risk level (9b)	Test Document (9c)	
62.	Vendor documents	Technical documentation from vendor not adequate	Yes	Adequate technical documentation is basic GMP requirement	No	NA	High	Vendor documentation (English) shall comprise at least: <ul style="list-style-type: none"> <li>➤ DQ, IQ and OQ</li> <li>➤ Material certificates</li> <li>➤ O &amp; M manual</li> <li>➤ Calibration certificates</li> <li>➤ Software backup</li> <li>➤ Change Parts list (sufficient detailed – part no., supplier, type)</li> <li>➤ Drawings: <ul style="list-style-type: none"> <li>- P&amp;I-diagrams</li> <li>- Electrical diagrams</li> <li>-As built GA drawing</li> </ul> </li> <li>➤ Filter certificates</li> <li>➤ Hydrotest Report</li> <li>➤ Running trial certificate.</li> </ul> Certificate of bought out components.	Acceptable	IQ	



## RISK ASSESSMENT FOR COMPRESSED AIR SYSTEM

### 8 Summary & Conclusion

- The Risk Assessment was performed to establish the design parameters of the equipment so as to meet the desired performance of the equipment i.e. Compressed Air System.
- The critical risks pertained to GMP and other than GMP, were analyzed with justification and mitigation procedures.
- For each recognized GMP-risk and other than GMP risks, necessary measures are defined. Organizational measures, like SOPs, are also possible measures for special GMP-risks. The availability of these SOPs will be checked during the performance of the OQ.
- The risks where conceptual procedures shall be employed, standard operating procedures (SOPs), Preventive maintenance schedules, Certificates and related documents indicated as mitigation procedures shall be ensured at respective test points

*"It is concluded that the **Risk Assessment** performed for the equipment will prevent the risk of failures of critical parameters during, design commissioning, installation, operation and performance of the equipment".*

### 9 Abbreviations

EU-GMP	:	European – Good Manufacturing Practice
EHS	:	Environment Health Safety
PLC	:	Programmable Logic Controller
MMI	:	Man Machine Interface
GMP	:	Good Manufacturing Practice
RA	:	Risk Assessment
NMT	:	Not More Than
SOP	:	Standard Operating Procedure
USFDA	:	United State Food & Drug Association
ISO	:	International Organization for Standardization
SS	:	Stainless Steel
db	:	Decibel
DQ	:	Design Qualification
IQ	:	Installation Qualification
OQ	:	Operational Qualification
PQ	:	Performance Qualification
O&M	:	Operation and Maintenance
GA	:	General Arrangement
IPSI	:	Integrated Project Services International, New Delhi

### 10 Revision History

Date	Revision	Reason for Revision
	00	New Document