

# PHARMA DEVILS

### **ENGINEERING DEPARTMENT**

STANDARD OPERATING PROCEDURE		
Department: Engineering	SOP No.:	
Title: Noise Level Measurement	Effective Date:	
Supersedes: Nil	Review Date:	
Issue Date:	Page No.:	

#### 1.0 REVISION HISTORY

Rev. No.	Details of changes	Reason for change
00	NIL	NEW SOP

#### **2.0 OBJECTIVE:**

**2.1** The Objective of this SOP is to describe the procedure for Noise level measurement.

#### 3.0 SCOPE:

**3.1** This SOP is to describe the procedure for Noise level measurement.

#### 4.0 **RESPONSIBILITY:**

- **4.1** The Maintenance Engineer shall be:
- **4.1.1** Responsible for checking the noise level measurement.
- **4.1.2** Responsible for corrective action in case of deviation.

#### **5.0 ACCOUNTABILITY:**

Head –Engineering Services

#### **6.0 PROCEDURE:**

- **6.1** Noise level measurement is to be done using a calibrated dB-Meter.
- **6.2** Switch 'On' the dB-Meter.
- **6.3** Hold the sensor of db meter at working height near equipment/system.
- **6.4** Check the noise level readings displayed on the meter.



# PHARMA DEVILS

## ENGINEERING DEPARTMENT

STANDARD OPERATING PROCEDURE		
Department: Engineering	SOP No.:	
Title: Noise Level Measurement	<b>Effective Date:</b>	
Supersedes: Nil	<b>Review Date:</b>	
Issue Date:	Page No.:	

- **6.5** Record the readings.
- **6.6** Switch 'Off' the dB-Meter.
- 6.7 Noise level should not be more then 85 dB.
- **7.0** ANNEXURES:

NIL

8.0 References (S)

NIL

9.0 Glossary

SOP: Standard Operating procedure

No. : Number