

WAREHOUSE LIMITS

1. In RLAF, the reading of Magnehelic Gauge across Pre-filter: 7-13 mm of WC
2. In RLAF, the reading of Magnehelic Gauge across HEPA filter: 15-30 mm of WC
3. In RLAF, the reading of Magnehelic Gauge across Exhaust HEPA filter: 15-30 mm of WC
4. Operating limit of Temperature in Store Areas: 19-25°C
5. Operating limit of Relative Humidity in RM Dispensing Booth: 45-55%
6. Operating limit of Relative Humidity in Store areas: 40-60%
7. Use of Sodium Lauryl Sulphate for Cleaning Sampling & Dispensing Tools: 0.1%
8. Deep Freezer Temperature: 2-8°C.
9. External Surface of Tools shall be sanitized by using IPA: 70%
10. Decontamination shall be done by using: 2.5% Sodium Hypochlorite for 30 minutes
11. In Dynamic Pass Box, the pressure drop across the HEPA filter: 10-20 mm on Magnehelic Gauge.
12. In Dynamic Pass Box, the pre-filter pressure should be: 0.6-4.0 mm of Water.
13. In Dynamic Pass Box, the HEPA filter pressure should be: 5-15 mm of Water.

