



# PHARMA DEVILS

QUALITY ASSURANCE DEPARTMENT

## FAILURE MODE EFFECT ANALYSIS FOR PURIFIED WATER GENERATION & DISTRIBUTION SYSTEM

S.No.	Item/ Function	Potential Failure Mode (Failure Mode )	Potential Effect of Failure (Effect)	Potential Cause/ Mechanism of Failure	Current Control	Reference	S	O	D	Risk Priority Number (S*O*D)	Recommend-ended Actions (if any)	Post Risk			
												S	O	D	RPN S*O *D
<b>Purified water Generation system:</b>															
1	<b>Bore well water</b>	➤ Increased microbial and particle contamination of the in-feed raw water.	➤ Can cause to contaminate the final product.	➤ The system shall be inefficient to remove the increased microbial and particulate contamination.	➤ The raw water from the bore well has been transferred to a closed underground storage tank. ➤ The transfer piping has been provided with the facility for automatically adding NAOCL Solution in line to raw water.	IQ & Qualification document	4	2	1	8 Low category & Risk Accepted	Adequate procedure no recommendation required.	NA	NA	NA	NA
2	<b>Bore well water</b>	➤ Insufficient quantity of raw water	➤ The quantity of raw water shall not have any impact on the product quality. ➤ The process may stop due to lack of raw water.	➤ Bore well not working properly. ➤ SOP for bore well operation not handle properly.	➤ 02 nos. of bore well are there in plant for full fill the required quantity of raw water.	IQ & Qualification document	1	2	1	2 Low category & Risk Accepted	Adequate procedure no recommendation required.	NA	NA	NA	NA
3	<b>Bore well water</b>	➤ Tank wall & floor is not leak proof.	➤ Water may be contaminated by sewage water or contaminated by heavy minerals.	➤ Unexpected intrusion of micro organism.	➤ Tank should have suitable construction of RCC and tank must be checked on regular basis for any crack.	IQ & Qualification document	4	1	1	4 Low category & Risk Accepted	Adequate procedure no recommendation required	NA	NA	NA	NA



# PHARMA DEVILS

QUALITY ASSURANCE DEPARTMENT

## FAILURE MODE EFFECT ANALYSIS FOR PURIFIED WATER GENERATION & DISTRIBUTION SYSTEM

S.No.	Item/ Function	Potential Failure Mode (Failure Mode )	Potential Effect of Failure (Effect)	Potential Cause/ Mechanism of Failure	Current Control	Reference	S	O	D	Risk Priority Number (S*O*D)	Recommend-ends Actions (if any)	Post Risk			
												S	O	D	RPN S*O *D
4	Raw water	➤ Water stagnant in underground tank.	➤ The water stagnant will raise the microbial content in the water.	➤ Not a proper cleaning of underground raw water tank. ➤ No training provided to persons.	➤ An online sodium hypochlorite dosing in water is considered with sampling points. ➤ During validation sanitization process and frequency has been established. ➤ SOP has been written, confirmed and implemented.	IQ & Qualification document	4	1	1	4 Low category & Risk Accepted	Adequate procedure no recommendation required.	NA	NA	NA	NA
5	Raw water tank	➤ Cleaning of underground storage tank is done on regularly.	➤ After a long period of time the microbial and particulate contamination may be increased and the system may be inefficient to remove the increased microbial and particulate contamination.	➤ No proper entry for cleaning in regular interval. ➤ No training provided to persons.	➤ The tank has been provided with man entry for cleaning in regular interval. ➤ The SOP for cleaning has been prepared and the frequency of the cleaning established.	Qualification document	3	1	1	3 Low category & Risk Accepted	Adequate procedure no recommendation required.	NA	NA	NA	NA
6	Chlorine level	➤ Low chemical level in dosing tank.	➤ Low level of chemical will not disinfect as per the requirement.	➤ No proper quantity of chemical is in dosing tank. ➤ No level sensors are there for provide a low level of chlorine.	➤ Level sensor has been provided in case of low level of chlorine in dosing tank.	IQ & Qualification document	3	2	1	6 Low category & Risk Accepted	Adequate procedure no recommendation required.	NA	NA	NA	NA



# PHARMA DEVILS

QUALITY ASSURANCE DEPARTMENT

## FAILURE MODE EFFECT ANALYSIS FOR PURIFIED WATER GENERATION & DISTRIBUTION SYSTEM

S.No.	Item/ Function	Potential Failure Mode (Failure Mode )	Potential Effect of Failure (Effect)	Potential Cause/ Mechanism of Failure	Current Control	Reference	S	O	D	Risk Priority Number (S*O*D)	Recommend-ended Actions (if any)	Post Risk			
												S	O	D	RPN S*O *D
7	<b>Chlorination of raw water</b>	➤ Chlorination of raw water failure	➤ Raw water Chemically & microbial contamination increases	<ul style="list-style-type: none"> <li>➤ Chlorine dosing system not working properly</li> <li>➤ Chlorine dosing tank not cleaned</li> <li>➤ SOP of chlorination of raw water not followed</li> </ul>	<ul style="list-style-type: none"> <li>➤ Calibrated dosing pump is in used for chlorine dosing for checking its working efficiency.</li> <li>➤ Chlorination of raw water is done as per its SOP.</li> <li>➤ Training provided.</li> </ul>	IQ & Qualification document	4	2	1	8 Low category & Risk Accepted.	Adequate procedure no recommendation required.	NA	NA	NA	NA
8	<b>Cleaning of chlorinated raw water tank</b>	➤ Chlorinated raw water tank Not Cleaned.	➤ Chlorinated raw water tank chance to increased level of contamination.	<ul style="list-style-type: none"> <li>➤ Cleaning of raw water tank not done</li> <li>➤ Personnel involved in operation lack of adequate knowledge</li> <li>➤ SOP of cleaning of raw water tank not followed.</li> </ul>	<ul style="list-style-type: none"> <li>➤ Cleaning of chlorinated water tank done on monthly basis.</li> <li>➤ All involve persons are trained.</li> </ul>	As per SOP	4	1	1	4 Low category & Risk Accepted.	Adequate procedure no recommendation required.	NA	NA	NA	NA
9	<b>Multi grade filter</b>	➤ Choking of the filters	<ul style="list-style-type: none"> <li>➤ Choking of the filters shall have no impact on the product quality.</li> <li>➤ Choked filters can reduce the quantity of filtration.</li> </ul>	<ul style="list-style-type: none"> <li>➤ Frequent removal of the filters.</li> <li>➤ Suspended solid particles from Borewell can cause the choking of filters.</li> <li>➤ Not proper washing of filter.</li> </ul>	<ul style="list-style-type: none"> <li>➤ Multi grade filter has dismountable type for easy removal and installation.</li> <li>➤ Installing of Pressure Gauge at the inlet of MGF and across the filter to detect the chock.</li> <li>➤ Sampling Point has been provided at inlet and outlet.</li> <li>➤ Backwash with high flow rate.</li> </ul>	Qualification document	3	2	1	6 Low category & Risk Accepted.	Adequate procedure no recommendation required.	NA	NA	NA	NA



# PHARMA DEVILS

QUALITY ASSURANCE DEPARTMENT

## FAILURE MODE EFFECT ANALYSIS FOR PURIFIED WATER GENERATION & DISTRIBUTION SYSTEM

S.No.	Item/ Function	Potential Failure Mode (Failure Mode )	Potential Effect of Failure (Effect)	Potential Cause/ Mechanism of Failure	Current Control	Reference	S	O	D	Risk Priority Number (S*O*D)	Recommend-ended Actions (if any)	Post Risk			
												S	O	D	RPN S*O *D
10	<b>Multi grade filter</b>	➤ Microbial growth in filters.	➤ It can be increase the level of microbes in raw water.	➤ During non operation of the system the water hold up will be stagnant and Possibility for microbial growth.	➤ Whole installation has been designed as complete drainable type to avoid such hold up and pressure Gauges are also installed. ➤ As the water is chlorinated the possibility of microbial growth is considerable less.	IQ & Qualification document	4	1	1	4 Low category & Risk Accepted	Adequate procedure no recommendation required.	NA	NA	NA	NA
12	<b>MGF Back Wash &amp; rinse</b>	➤ Multi-grade filter back wash & rinse Failure.	➤ Suspended solids & dirt increases in raw water.	➤ Back wash & rinse of multi-grade filter not done. ➤ Working personnel inadequate of knowledge. ➤ Back wash &rinse of multi-grade filter sop not followed.	➤ Back wash & rinse of multi-grade filter done on daily basis as 24 hours once in time and the time duration is on automatic mode. ➤ Cleaning (back wash) is done as per sop by trained persons.	Qualification document	3	3	1	9 Low category & Risk Accepted	Adequate procedure no recommendation required.	NA	NA	NA	NA
13	<b>Softener Charging &amp; rinsing</b>	➤ Softener charging failure.	➤ Hardness of raw water increased	➤ Charging of softener & rinsing not done. ➤ Personnel doing softener charging inadequate knowledge. ➤ SOP for softener charging & rinsing not followed.	➤ Charging of softener & rinsing done automatically after every 1440 min. as per the sop and done by trained person.	As per SOP	3	2	1	6 Low category & Risk Accepted	Adequate procedure no recommendation required.	NA	NA	NA	NA



# PHARMA DEVILS

QUALITY ASSURANCE DEPARTMENT

## FAILURE MODE EFFECT ANALYSIS FOR PURIFIED WATER GENERATION & DISTRIBUTION SYSTEM

S.No.	Item/ Function	Potential Failure Mode (Failure Mode )	Potential Effect of Failure (Effect)	Potential Cause/ Mechanism of Failure	Current Control	Reference	S	O	D	Risk Priority Number (S*O*D)	Recommend-ended Actions (if any)	Post Risk			
												S	O	D	RPN S*O *D
14	<b>Soft water storage tank cleaning &amp; Sanitization</b>	➤ Cleaning & sanitization of soft water storage tank not done	➤ Chemical & microbial contamination level in soft water increased.	<ul style="list-style-type: none"> <li>➤ Cleaning &amp; sanitization of soft water storage tank not done</li> <li>➤ Working personnel lack of adequate knowledge</li> <li>➤ Soft water storage tank cleaning &amp; sanitization sop not followed.</li> </ul>	➤ Cleaning & sanitization of soft water storage tank done on monthly basis as per the sop and done by trained person.	Qualification document	4	1	1	4 Low category & Risk Accepted	Adequate procedure no recommendation required.	NA	NA	NA	NA
15	<b>UF cartridge filter (0.03µ ) pressurized</b>	➤ UF cartridge filter choked or pressurized.	<ul style="list-style-type: none"> <li>➤ Required quantity of ultra filtered not available for normal operation of UF system.</li> <li>➤ Suspended solid increased affected UF water quality.</li> <li>➤ Leakage of UF system.</li> <li>➤ Microbial contamination increases in UF water.</li> </ul>	<ul style="list-style-type: none"> <li>➤ Replacement of cartridge filter not done.</li> <li>➤ Working personnel lack of adequate knowledge.</li> <li>➤ Monthly sanitization sop not followed.</li> <li>➤ Daily basis cartridge filter pressure not checked</li> <li>➤ Replacement of cartridge filter not done.</li> <li>➤ Cartridge filter replacement sop not followed.</li> </ul>	<ul style="list-style-type: none"> <li>➤ Replacement of cartridge filter done.</li> <li>➤ Training provided.</li> <li>➤ Monthly sanitization sop are followed.</li> <li>➤ Daily basis cartridge filter pressure checked.</li> </ul>	Qualification document	4	3	1	12 Low category and Risk accepted	Adequate procedure no recommendation required.	NA	NA	NA	NA
16	<b>UF system backwash &amp; back flushing</b>	➤ UF system backwash & back flushing failure	➤ Back wash & flushing of UF system not done automatically by system.	<ul style="list-style-type: none"> <li>➤ Back wash &amp; flushing of UF system automatically not done at interval of every 60 minutes during system in operation continuously.</li> <li>➤ Working personnel lack of adequate knowledge</li> </ul>	<ul style="list-style-type: none"> <li>➤ UF Back wash &amp; flushing automatically done at interval of every 600 minutes during system in operation continuously.</li> <li>➤ Training provided.</li> </ul>	As per sop.	3	3	1	9 Low category and Risk accepted	Adequate procedure no recommendation required.	NA	NA	NA	NA



# PHARMA DEVILS

QUALITY ASSURANCE DEPARTMENT

## FAILURE MODE EFFECT ANALYSIS FOR PURIFIED WATER GENERATION & DISTRIBUTION SYSTEM

S.No.	Item/ Function	Potential Failure Mode (Failure Mode )	Potential Effect of Failure (Effect)	Potential Cause/ Mechanism of Failure	Current Control	Reference	S	O	D	Risk Priority Number (S*O*D)	Recommend-ended Actions (if any)	Post Risk			
												S	O	D	RPN S*O *D
17	<b>UF storage tank cleaning &amp; sanitization</b>	➤ Cleaning & sanitization of UF water storage tank not done.	➤ Chemical & microbial contamination level in UF water storage increased.	➤ Cleaning & sanitization of UF water storage tank not done ➤ Working personnel lack of adequate knowledge ➤ UF water storage tank cleaning & sanitization sop not followed.	➤ Cleaning & sanitization of soft water storage tank done on monthly basis as per sop by the trained persons.	As per sop.	3	1	1	6 Low category and Risk accepted	Adequate procedure no recommendation required.	NA	NA	NA	NA
18	<b>SMBS Dosing system &amp; storage tank cleaning</b>	➤ Sodium meta bisulphate dosing system failure	➤ Chlorine not removed from RO water. ➤ Excess Chlorine get damaged RO membrane	➤ Sodium meta bi sulphite dosing pump not working ➤ SMBS dosing supply Interrupted. ➤ SMBS dosing pump not calibrated ➤ Working personnel lack of adequate knowledge. ➤ Cleaning of SMBS dosing not followed as per sop. ➤ Dosing of SMBS not followed as per sop	➤ Sodium meta bi sulphite dosing pump working ➤ SMBS dosing supply daily basis checked & updated dosing system status. ➤ Training provided. ➤ Cleaning of SMBS dosing tank after consumption of solution on daily basis before freshly prepared dosing solution in dosing tank follow as per sop. ➤ Dosing of SMBS followed as per sop. ➤ ORP sensor provided after dosing.	As per SOP.	3	3	2	18 Low category and Risk accepted	Adequate procedure no recommendation required.	NA	NA	NA	NA



# PHARMA DEVILS

QUALITY ASSURANCE DEPARTMENT

## FAILURE MODE EFFECT ANALYSIS FOR PURIFIED WATER GENERATION & DISTRIBUTION SYSTEM

S.No.	Item/ Function	Potential Failure Mode (Failure Mode )	Potential Effect of Failure (Effect)	Potential Cause/ Mechanism of Failure	Current Control	Reference	S	O	D	Risk Priority Number (S*O*D)	Recommend-ended Actions (if any)	Post Risk			
												S	O	D	RPN S*O *D
19	SMBS dosing	➤ Chlorine content high.	➤ The chlorine content in water shall lead to oxidation of the RO membrane and hence shall affect the final water quality.	<ul style="list-style-type: none"> <li>➤ SMBS dosing supply Interrupted.</li> <li>➤ SMBS dosing pump not calibrated</li> <li>➤ ORP Sensor not provided or working.</li> </ul>	<ul style="list-style-type: none"> <li>➤ The dosing unit has been provided for sodium meta-bi-sulfite (SMBS) addition to the water.</li> <li>➤ The ORP sensor has been provided for monitoring the chlorine content of water with auto dump valve.</li> </ul>	As per SOP & Qualification document	3	2	1	6 Low category and Risk accepted	Adequate procedure no recommendation required.	NA	NA	NA	NA
20	Anti Scalent dosing system & Cleaning	➤ Anti dosing failure	<ul style="list-style-type: none"> <li>➤ Scaling of water increased in tube &amp; RO water pipe line.</li> <li>➤ Scaling causes microbial load increased frequently RO membrane get damaged with flow decline</li> </ul>	<ul style="list-style-type: none"> <li>➤ Anti Scalent dosing pump not working</li> <li>➤ Anti Scalent dosing supply Interrupted.</li> <li>➤ Anti Scalent dosing pump not calibrated</li> <li>➤ Working personnel lack of adequate knowledge.</li> <li>➤ Cleaning of Anti Scalent dosing not followed as per sop.</li> <li>➤ Dosing of Anti Scalent not followed as per sop</li> </ul>	<ul style="list-style-type: none"> <li>➤ Anti Scalent dosing pump working.</li> <li>➤ Anti Scalent dosing supply, Daily basis checked &amp; updated dosing system status.</li> <li>➤ Anti Scalent dosing pump calibrated as per schedule.</li> <li>➤ Training provided.</li> <li>➤ Cleaning of Anti Scalent dosing tank after consumption of solution on daily basis before freshly prepared dosing solution in dosing tank follow as per sop.</li> </ul>	As per sop.	3	1	1	3 Low category and Risk accepted	Adequate procedure no recommendation required.	NA	NA	NA	NA



# PHARMA DEVILS

QUALITY ASSURANCE DEPARTMENT

## FAILURE MODE EFFECT ANALYSIS FOR PURIFIED WATER GENERATION & DISTRIBUTION SYSTEM

S.No.	Item/ Function	Potential Failure Mode (Failure Mode )	Potential Effect of Failure (Effect)	Potential Cause/ Mechanism of Failure	Current Control	Reference	S	O	D	Risk Priority Number (S*O*D)	Recommend-ended Actions (if any)	Post Risk			
												S	O	D	RPN S*O *D
21	<b>AUTO pH dosing system &amp; cleaning</b>	➤ Auto pH Dosing system failure	➤ pH not maintained in RO water ➤ Excessive production of CO <sub>2</sub> in closed pipe line system.	➤ Sodium hydroxide dosing pump not working. ➤ Sodium hydroxide dosing supply interrupted. ➤ Sodium hydroxide dosing pump not calibrated. ➤ Working personnel lack of adequate knowledge. ➤ Cleaning of Sodium hydroxide dosing not followed as per sop. ➤ Dosing of Sodium hydroxide not followed as per sop.	➤ Sodium hydroxide dosing pump working. ➤ Sodium hydroxide dosing supply, Daily basis checked. & updated dosing system status. ➤ Sodium hydroxide dosing pump calibrated as per schedule. ➤ Training provided. ➤ Cleaning of Sodium hydroxide dosing tank after consumption of solution on daily basis before freshly prepared dosing solution in dosing tank follow as per Sop.	As per SOP & Qualification document	4	3	1	12 Low category and Risk accepted	Adequate procedure no recommendation required.	NA	NA	NA	NA
22	➤ <b>5μ cartridge filter choked or pressurized</b>	➤ 5μ cartridge filter choked or pressurized	➤ Required quantity of water not available for normal operation of RO Pump. ➤ Suspended solid increased affected RO Feed water quality. ➤ Leakage of cartridge housing system ➤ Microbial contamination increases in RO water.	➤ Replacement of cartridge filter not done ➤ Working personnel lack of adequate knowledge ➤ Monthly sanitization sop not followed ➤ Daily basis cartridge filter pressure not checked ➤ Replacement of cartridge filter not done ➤ Cartridge filter replacement sop not followed	➤ Training provided. ➤ daily basis cartridge filter pressure monitoring in recorded ➤ Cartridge filter replacement followed.	As per SOP & Qualification document	4	2	2	16 Low category and Risk accepted	Adequate procedure no recommendation required.	NA	NA	NA	NA





# PHARMA DEVILS

QUALITY ASSURANCE DEPARTMENT

## FAILURE MODE EFFECT ANALYSIS FOR PURIFIED WATER GENERATION & DISTRIBUTION SYSTEM

S.No.	Item/ Function	Potential Failure Mode (Failure Mode )	Potential Effect of Failure (Effect)	Potential Cause/ Mechanism of Failure	Current Control	Reference	S	O	D	Risk Priority Number (S*O*D)	Recommend-ended Actions (if any)	Post Risk			
												S	O	D	RPN S*O *D
23	<b>RO high pressure pump low pressure</b>	➤ ROHP Failure	➤ Low pressure of water causing failure to start of ROHP pump.	<ul style="list-style-type: none"> <li>➤ ROHP interlocking system not working</li> <li>➤ Working personnel lack of adequate knowledge.</li> <li>➤ preventive maintenance not done as per schedule</li> </ul>	<ul style="list-style-type: none"> <li>➤ ROHP interlocking system working</li> <li>➤ working personnel provide training</li> <li>➤ preventive maintenance done as per schedule</li> </ul>	As per SOP & Qualification document	3	3	1	9 Low category and Risk accepted	Adequate procedure no recommendation required.	NA	NA	NA	NA
24	<b>RO membrane I &amp; II pressurized /Choked</b>	➤ RO membrane Pressurized RO water flow very low output of water	<ul style="list-style-type: none"> <li>➤ Very low flow final out put volume of RO water decreases of purified water.</li> <li>➤ RO water generation.</li> <li>➤ Leakage of RO membrane system.</li> </ul>	<ul style="list-style-type: none"> <li>➤ Required quantity of RO water not available.</li> <li>➤ Pressure gauge not calibrated.</li> <li>➤ Sanitization of RO membrane not done as per schedule.</li> <li>➤ Microbial contamination increases in RO water.</li> <li>➤ Interlocking system not working.</li> <li>➤ Preventive maintenance not done as per schedule.</li> <li>➤ Working personnel lack of adequate knowledge.</li> </ul>	<ul style="list-style-type: none"> <li>➤ Replacement of RO membrane.</li> <li>➤ Pressure gauge calibration done as per schedule.</li> <li>➤ Result of microbial with in limit as per trending.</li> <li>➤ Interlocking system Properly Working.</li> </ul>	As per SOP & Qualification document	3	3	2	18 Low category and Risk accepted	Adequate procedure no recommendation required.	NA	NA	NA	NA
25	<b>Industrial RO Unit (RO-I &amp; II)</b>	➤ No provision for Sampling after RO	➤ RO unit is required to generate process water, required for purified water Generation system. Water quality shall not be checked.	<ul style="list-style-type: none"> <li>➤ No sampling points provided for sampling after RO I &amp; II.</li> <li>➤ No Training provided to person.</li> <li>➤ Sop for sampling is not followed.</li> </ul>	<ul style="list-style-type: none"> <li>➤ Industrial RO unit has been provided where water is separated from dissolved salts in solution by filtering through a semi permeable membrane.</li> <li>➤ Sampling point after RO has been provided.</li> </ul>	As per SOP & Qualification document	4	1	1	4 Low category and Risk accepted	Adequate procedure no recommendation required.	NA	NA	NA	NA



# PHARMA DEVILS

QUALITY ASSURANCE DEPARTMENT

## FAILURE MODE EFFECT ANALYSIS FOR PURIFIED WATER GENERATION & DISTRIBUTION SYSTEM

S.No.	Item/ Function	Potential Failure Mode (Failure Mode )	Potential Effect of Failure (Effect)	Potential Cause/ Mechanism of Failure	Current Control	Reference	S	O	D	Risk Priority Number (S*O*D)	Recommend-ended Actions (if any)	Post Risk			
												S	O	D	RPN S*O *D
26	<b>Conductivity of RO System More than specified limit</b>	➤ RO conductivity high	➤ RO water conductivity increased finally chances to purified water conductivity raises manufacturing product may be degraded or detonated.	<ul style="list-style-type: none"> <li>➤ Conductivity sensor with monitor malfunctioning.</li> <li>➤ Microbial load increased</li> <li>➤ Sanitization of RO membrane not done as per schedule.</li> <li>➤ Microbial contamination increases in RO water.</li> <li>➤ Interlocking system failure</li> <li>➤ Working personnel lack of adequate knowledge.</li> <li>➤ Preventive maintenance not done as per schedule</li> </ul>	<ul style="list-style-type: none"> <li>➤ On line conductivity monitored inbuilt in RO system</li> <li>➤ Conductivity sensor Interlocking with HMI, dumping valve open do not feed RO water for EDI still within 5 minutes conductivity in range either RO plant tripped</li> <li>➤ Calibrated conductivity monitor with sensor used for RO System.</li> <li>➤ Sanitization of RO membrane done as per schedule.</li> <li>➤ Microbial contamination increases in RO water.</li> <li>➤ Interlocking system working properly.</li> <li>➤ Preventive maintenance done as per schedule.</li> </ul>	As per sop & IQ	4	3	1	12 Low category and Risk accepted	Adequate procedure no recommendation required.	NA	NA	NA	NA
27	<b>Industrial RO Unit (RO-I &amp; II)</b>	➤ Water quality fails at out let of RO+EDI unit.	➤ Water quality didn't meet the specified conductivity.	<ul style="list-style-type: none"> <li>➤ RO conductivity high</li> <li>➤ Working personnel lack of adequate knowledge.</li> <li>➤ Preventive maintenance not done as per schedule</li> </ul>	<ul style="list-style-type: none"> <li>➤ The water has been dumped and recalculated to soft water tank.</li> </ul>	As per SOP & Qualification document	3	3	1	9 Low category and Risk accepted	Adequate procedure no recommendation required.	NA	NA	NA	NA



# PHARMA DEVILS

QUALITY ASSURANCE DEPARTMENT

## FAILURE MODE EFFECT ANALYSIS FOR PURIFIED WATER GENERATION & DISTRIBUTION SYSTEM

S.No.	Item/ Function	Potential Failure Mode (Failure Mode )	Potential Effect of Failure (Effect)	Potential Cause/ Mechanism of Failure	Current Control	Reference	S	O	D	Risk Priority Number (S*O*D)	Recommend-ended Actions (if any)	Post Risk			
												S	O	D	RPN S*O *D
28	<b>EDI feed pressure low</b>	<ul style="list-style-type: none"> <li>➤ EDI flow low</li> </ul>	<ul style="list-style-type: none"> <li>➤ Very low flow final out put volume reduced of purified water.</li> <li>➤ EDI Tripped within 5 minutes not maintained whole plant tripped.</li> <li>➤ EDI drainage of concentrated more than specified amount.</li> </ul>	<ul style="list-style-type: none"> <li>➤ EDI chocked or pressurized</li> <li>➤ Pressure gauge not calibrated</li> <li>➤ Sanitization of EDI membrane not done as per schedule.</li> <li>➤ Microbial contamination increases in RO water.</li> <li>➤ Pressure switch with Interlocking system not working.</li> <li>➤ Preventive maintenance not done as per schedule.</li> <li>➤ Working personnel lack of adequate knowledge.</li> </ul>	<ul style="list-style-type: none"> <li>➤ Pressure gauge calibration done as per schedule.</li> <li>➤ Result of microbial with in limit as per trending.</li> <li>➤ Interlocking system Properly Working.</li> </ul>	As per SOP & Qualification document	3	3	1	9 Low category and Risk accepted	Adequate procedure no recommendation required.	NA	NA	NA	NA
29	<b>EDI</b>	<ul style="list-style-type: none"> <li>➤ Various process parameters like pH, conductivity, flow rate, TOC are not monitored.</li> <li>➤ Sampling not done after EDI.</li> </ul>	<ul style="list-style-type: none"> <li>➤ Critical GMP process parameter water quality shall not be checked</li> </ul>	<ul style="list-style-type: none"> <li>➤ Sampling point after EDI not provided.</li> <li>➤ EDI didn't have provision to monitor the check parameters.</li> </ul>	<ul style="list-style-type: none"> <li>➤ The unit has been provided with the Provision for monitoring, indicating and controlling the pH, conductivity and flow rate of water.</li> <li>➤ Sampling point after EDI has been provided.</li> <li>➤ Sampling done as per schedule.</li> </ul>	As per SOP & Qualification document	4	3	1	12 Low category and Risk accepted	Adequate procedure no recommendation required.	NA	NA	NA	NA



# PHARMA DEVILS

QUALITY ASSURANCE DEPARTMENT

## FAILURE MODE EFFECT ANALYSIS FOR PURIFIED WATER GENERATION & DISTRIBUTION SYSTEM

S.No.	Item/ Function	Potential Failure Mode (Failure Mode )	Potential Effect of Failure (Effect)	Potential Cause/ Mechanism of Failure	Current Control	Reference	S	O	D	Risk Priority Number (S*O*D)	Recommend-ended Actions (if any)	Post Risk			
												S	O	D	RPN S*O *D
30	<b>EDI conductivity more than Specified limit</b>	➤ EDI conductivity high	➤ Pharmaceutical Product degraded or Deteriorated.	<ul style="list-style-type: none"> <li>➤ EDI Conductivity sensor with monitor malfunctioning.</li> <li>➤ Microbial load increased</li> <li>➤ Sanitization of EDI not done as per schedule.</li> <li>➤ EDI conductivity interlocking system failure.</li> <li>➤ Working personnel lack of adequate knowledge.</li> <li>➤ Preventive maintenance not done as per schedule.</li> </ul>	<ul style="list-style-type: none"> <li>➤ EDI conductivity sensor with monitor calibrated working properly daily basis operation checked.</li> <li>➤ EDI conductivity Interlocking system working properly with auto dumping valve facility controlled by HMI.</li> <li>➤ Working personnel lack of adequate knowledge.</li> <li>➤ Preventive maintenance Done as per schedule</li> <li>➤ Training provided</li> </ul>	As per SOP & Qualification document	4	2	1	8 Low category and Risk accepted	Adequate procedure no recommendation required.	NA	NA	NA	NA
31	<b>Purified water Storage Tank</b>	➤ No storage of purified water before use.	<ul style="list-style-type: none"> <li>➤ The water quality shall not be affected if not stored.</li> <li>➤ It is difficult for providing several user points from the single point of generation.</li> </ul>	➤ Un-availability of purified water storage tank.	➤ The generated purified water has been stored in a storage tank (purified water storage tank).	As per SOP & Qualification document	3	1	1	3 Low category and Risk accepted	Adequate procedure no recommendation required.	NA	NA	NA	NA
32	<b>Purified water Storage Tank</b>	➤ Low water level in the storage tank.	<ul style="list-style-type: none"> <li>➤ The water level shall not affect the water quality.</li> <li>➤ No water in the tank, the Pump will run dry. It may lead to damage the pump and affect the process.</li> </ul>	➤ Manual observation of the water level is difficult.	➤ The storage tank has been provided with level sensor for water low & high level.	As per SOP & Qualification document	3	1	1	3 Low category and Risk accepted	Adequate procedure no recommendation required.	NA	NA	NA	NA



# PHARMA DEVILS

QUALITY ASSURANCE DEPARTMENT

## FAILURE MODE EFFECT ANALYSIS FOR PURIFIED WATER GENERATION & DISTRIBUTION SYSTEM

S.No.	Item/ Function	Potential Failure Mode (Failure Mode )	Potential Effect of Failure (Effect)	Potential Cause/ Mechanism of Failure	Current Control	Reference	S	O	D	Risk Priority Number (S*O*D)	Recommend-ended Actions (if any)	Post Risk			
												S	O	D	RPN S*O *D
33	<b>Purified water storage tank &amp; loop sanitization</b>	<ul style="list-style-type: none"> <li>➤ Purified water storage &amp; Distribution system sanitization failure</li> </ul>	<ul style="list-style-type: none"> <li>➤ Microbial ,chemical contamination increases</li> <li>➤ Germs increases in purified water</li> <li>➤ Pharmaceutical product may be degraded or decay earliest before expiry</li> </ul>	<ul style="list-style-type: none"> <li>➤ Plant steam required pressure not maintained regularly during system sanitization</li> <li>➤ Sanitization temperature &amp; time duration not maintained.</li> <li>➤ Sanitization process interrupted as utility failure</li> <li>➤ Temperature sensor mal functioning</li> <li>➤ Sanitization properly not done as schedule de frequency</li> <li>➤ Storage &amp; distribution system required temperature not achieved during time for sanitization.</li> <li>➤ Conductivity may be increased</li> <li>➤ Working personnel lack of adequate knowledge.</li> <li>➤ Purified water storage &amp; distribution system leakage.</li> <li>➤ Preventive maintenance not done as per schedule.</li> </ul>	<ul style="list-style-type: none"> <li>➤ As required plant Steam pressure are available for sanitization</li> <li>➤ Sanitization temperature &amp; time duration maintained as required for sanitization</li> <li>➤ Time of sanitization process no any long time utility failure</li> <li>➤ Temperature sensor calibrated as per schedule.</li> <li>➤ Sanitization done properly as per mentioned schedule as frequency monthly</li> <li>➤ Storage &amp; distribution system Sanitization temperature maintained.</li> <li>➤ On line Conductivity sensor in return loop calibrated as per schedule</li> <li>➤ No any leakage found in system</li> </ul>	As per SOP & Qualification document	5	2	1	10 Medium category and Risk accepted	Adequate procedure no recommendation required.	NA	NA	NA	NA
34	<b>Purified water storage tank vent filter integrity</b>	<ul style="list-style-type: none"> <li>➤ Vent filter integrity failure</li> </ul>	<ul style="list-style-type: none"> <li>➤ Microbial contamination over</li> <li>➤ Tank pressurized</li> </ul>	<ul style="list-style-type: none"> <li>➤ Filter integrity testing not done as per schedule.</li> <li>➤ Handling of vent filter not properly</li> <li>➤ Vent filter choked</li> <li>➤ Working personnel lack of adequate knowledge.</li> </ul>	<ul style="list-style-type: none"> <li>➤ Additional integrity tested filter available</li> <li>➤ Handling of vent filter properly wrapped in Alu- foil.</li> <li>➤ Training provided</li> <li>➤ Before installed at tank integrity has been tested/checked.</li> </ul>	As per SOP & Qualification document	4	2	1	8 Medium category and Risk accepted	Adequate procedure no recommendation required.	NA	NA	NA	NA



# PHARMA DEVILS

QUALITY ASSURANCE DEPARTMENT

## FAILURE MODE EFFECT ANALYSIS FOR PURIFIED WATER GENERATION & DISTRIBUTION SYSTEM

S.No.	Item/ Function	Potential Failure Mode (Failure Mode )	Potential Effect of Failure (Effect)	Potential Cause/ Mechanism of Failure	Current Control	Reference	S	O	D	Risk Priority Number (S*O*D)	Recommend-ended Actions (if any)	Post Risk			
												S	O	D	RPN S*O *D
35	<b>Purified water Return loop conductivity more</b>	<ul style="list-style-type: none"> <li>➤ Return loop conductivity More</li> </ul>	<ul style="list-style-type: none"> <li>➤ Chemical Contamination</li> <li>➤ Pharmaceutical product may be degraded or decay earliest before expiry</li> </ul>	<ul style="list-style-type: none"> <li>➤ Malfunctioning of Conductivity sensor.</li> <li>➤ Microbial load may be increased.</li> <li>➤ Sanitization of purified return loop not done as per schedule.</li> <li>➤ Return loop auto dumping valve not working as per Interlocking system.</li> <li>➤ Working personnel lack of adequate knowledge.</li> <li>➤ Preventive maintenance not done as per schedule.</li> </ul>	<ul style="list-style-type: none"> <li>➤ Conductivity sensor of purified water return loop line are Calibrated as per schedule.</li> <li>➤ Sanitization of purified water loop done as per schedule monthly.</li> <li>➤ Return loop conductivity raises auto dumping valve effectively working as open still after 300 sec. finally entire system tripped.</li> <li>➤ Training provided</li> </ul>	As per SOP & Qualification document	5	2	1	10 Medium category and Risk accepted	Adequate procedure no recommendation required.	NA	NA	NA	NA
36	<b>Purified water return loop flow OR loop velocities</b>	<ul style="list-style-type: none"> <li>➤ Purified water return loop flow OR velocities Loop failure/not maintained.</li> </ul>	<ul style="list-style-type: none"> <li>➤ Microbial load may be increases.</li> <li>➤ May be Chances of Loop proliferation</li> <li>➤ Turbulent flow failure in loop</li> <li>➤ Product may be degraded before shelf life</li> </ul>	<ul style="list-style-type: none"> <li>➤ Loop Purified Pump water flow not full fill as per requirement.</li> <li>➤ Pipe size more than Pipe nominal size as per DQ Not maintained.</li> </ul>	<ul style="list-style-type: none"> <li>➤ Product handling SOP to be followed.</li> </ul>	As per SOP & Qualification document	3	2	1	6 Medium category and Risk accepted	Adequate procedure no recommendation required.	NA	NA	NA	NA
37	<b>Purified water supply loop line UV lamp failure/low intensity</b>	<ul style="list-style-type: none"> <li>➤ Purified water supply loop line UV lamp failure/low intensity</li> </ul>	<ul style="list-style-type: none"> <li>➤ Microbial ,chemical contamination increases</li> <li>➤ Germs increases in purified water</li> <li>➤ Pharmaceutical product may be degraded or decay earliest before expiry</li> </ul>	<ul style="list-style-type: none"> <li>➤ UV monitor &amp; sensor malfunctioning</li> <li>➤ UV meter not calibrated</li> <li>➤ Preventive maintenance not done as per schedule.</li> <li>➤ Burning hour completion</li> <li>➤ Alarming system not work system interlocking.</li> <li>➤ Working personnel lack of adequate knowledge.</li> </ul>	<ul style="list-style-type: none"> <li>➤ UV sensor/monitor system calibrated used.</li> <li>➤ 12000 hour completion/either low intensities.</li> <li>➤ Alarming system work as lamp failure &amp; low intensity.</li> <li>➤ All related Working personnel, Training provided.</li> </ul>	As per SOP & Qualification document	4	2	1	8 Low category and Risk accepted	Adequate procedure no recommendation required.	NA	NA	NA	NA



# PHARMA DEVILS

QUALITY ASSURANCE DEPARTMENT

## FAILURE MODE EFFECT ANALYSIS FOR PURIFIED WATER GENERATION & DISTRIBUTION SYSTEM

S.No.	Item/ Function	Potential Failure Mode (Failure Mode )	Potential Effect of Failure (Effect)	Potential Cause/ Mechanism of Failure	Current Control	Reference	S	O	D	Risk Priority Number (S*O*D)	Recommend-ended Actions (if any)	Post Risk			
												S	O	D	RPN S*O *D
38	<b>Purified water distribution</b>	<ul style="list-style-type: none"> <li>➤ Water stagnancy in the distribution line to different user Points.</li> <li>➤ No sampling point provided.</li> </ul>	<ul style="list-style-type: none"> <li>➤ Water contamination may increase due to the bio-load in the distribution line to different user points.</li> </ul>	<ul style="list-style-type: none"> <li>➤ Sampling point is not provided in loop and user points.</li> <li>➤ Removal of stagnant water each time before use shall be very difficult.</li> </ul>	<ul style="list-style-type: none"> <li>➤ The water distribution has been in a loop system. The water has in continuous flow in the loop.</li> <li>➤ All pipelines have drainable slope of &gt; 1:100.</li> <li>➤ The dead leg in the loop has been more than 1.5d. (d- diameter of the extended part)</li> <li>➤ Sampling points has been provided at return loop and all user points.</li> </ul>	As per SOP & Qualification document	4	1	1	4 Low category and Risk accepted	Adequate procedure no recommendation required.	NA	NA	NA	NA
39	<b>Purified water distribution</b>	<ul style="list-style-type: none"> <li>➤ Bio-film formation in the pipe.</li> </ul>	<ul style="list-style-type: none"> <li>➤ It can cause a contamination to the product.</li> </ul>	<ul style="list-style-type: none"> <li>➤ Flow rate in the loop is low &amp; Low flow rate tends to Bio-film formation in the pipe.</li> </ul>	<ul style="list-style-type: none"> <li>➤ Specified flow rate has been maintained in the loop at supply and return line.</li> <li>➤ Flow switch has been considered on the return line with VFD connection to the distribution pump.</li> </ul>	As per SOP & Qualification document	5	2	1	10 Low category and Risk accepted	Adequate procedure no recommendation required.	NA	NA	NA	NA

Where: S=Severity; O=Occurrence Probability; D=Detection

Remarks (if any):-

---



---



---



---



---



**PHARMA DEVILS**  
QUALITY ASSURANCE DEPARTMENT

**FAILURE MODE EFFECT ANALYSIS FOR PURIFIED WATER GENERATION & DISTRIBUTION SYSTEM**

Quality Risk Management Team			Reviewed By Head Operations Sign & Date	Approved By Head QA Sign & Date
Name	Department	Sign & Date		

**QUALITY RISK ASSESSEMENT AND MITIGATION SUMMARY REPORT**

Name of Facility/Equipment/Utility/System/Activity/Procedure/Unit Operation: Purified water generation & distribution system		Date:	
S. No.	Recommended Action	Responsible Person	Target Date of Completion
1.			
2.			

**Verification of Action Plan:**

All the above agreed actions completed, Not Completed.  
(\*incase any recommendations not completed, to be tracked through CAPA System)

**Remarks (if any):** NA

Verified By  
QA  
Sign & Date

Approved By  
Head QA  
Sign & Date