

QUALITY ASSURANCE DEPARTMENT

QUALITY RISK ASSESSEMENT AND MITIGATION PLAN

QRA No.:

Name of Facility/Equipment/Utility/System/Activity/Procedure

Unit Operation: Description: The objective of the risk assessment is to evaluate the risk associated during the Date of Quality Risk Assessment:

Sr.	Item/	Potential	Potential Effect of	Potential Cause/	Current Control	Reference	S	0	D	Risk	Recommend-		Post	Ris	ς.
No.	Function	Failure Mode (Failure Mode)	Failure (Effect)	Mechanism of Failure						Priority Number (S*O*D)	ended Actions (if any)	S	0	D	RPN S*O*D
1.	Before start of Dispensing	 Unapproved material gets dispense. Failed material gets dispense. 	 Unapproved dispense material leads to product contamination. Fails to achieve the safety, efficacy and quality of product. 	 Lack of Qualified source of API and excipients. Lack of testing specification. Lack of vendor management procedure. 	 Qualification procedure is in place and also line clearance check point is available in BMR to ensure approved & release materials are available for dispensing. Testing specifications are in place. Vendor management procedure is in place. 	Operation, cleaning, calibration and verification of weighing balance, Dispensing and issuance of RM and PM	4	1	1	4	NA	NA	NA	NA	NA



QUALITY ASSURANCE DEPARTMENT

QUALITY RISK ASSESSEMENT AND MITIGATION PLAN

QRA No.:

Name of Facility/Equipment/Utility/System/Activity/Procedure

Unit Operation: Description: The objective of the risk assessment is to evaluate the risk associated during the Date of Quality Risk Assessment:

Sr.	Item/	Potential	Potential Effect of	Potential Cause/	Current Control	Reference	S	0	D	Risk	Recommend-		Post	Ris	ζ.
No.	Function	Failure Mode (Failure Mode)	Failure (Effect)	Mechanism of Failure						Priority Number (S*O*D)	ended Actions (if any)	S	0		RPN S*O*I
2.	At the time of Dispensing	 Fails to dispense the required quantity. Dispense material get contaminate. 	 Inadequate result due to improper quantity dispensing and improper testing outcomes (OOS). Contamination of the area leads to product failure 	 Due to selection of wrong capacity weighing balance. Due to lack of operational and calibration procedure of weighing balance. Due to improper environmental conditions. Due to lack of the operation and cleaning procedure for dispensing tools. Due to lack of procedure for dispensing Material dispensed by untrained personnel. No cross check during dispensing Unapproved/rejected material dispensed. 	 Selection of weighing balance is depending on balance capacity and quantity of material. SOP is in place for operation and calibration procedure of weighing balances. Environmental condition check point is in place in line clearance checklist. Uses and cleaning of dispensing tool SOP is in place. Dispensing of API, excipients and PM SOP's are in place. Training has been imparted to concerned personnel's. In dispensing activity done by and checked by provision is available in BMR and verification done by before compounding. Check point is in place in BMR to check material is approved/released. 	Operation, Cleaning, Calibration and Verification of Weighing Balances, Dispensing and issuance of RM and Dispensing of PM	3	2		6	NA	NA	NA	NA	NA



QUALITY ASSURANCE DEPARTMENT

QUALITY RISK ASSESSEMENT AND MITIGATION PLAN

QRA No.:

Name of Facility/Equipment/Utility/System/Activity/Procedure

Unit Operation: Description: The objective of the risk assessment is to evaluate the risk associated during the Date of Quality Risk Assessment:

Sr.	Item/	Potential	Potential Effect of	Potential Cause/	Current Control	Reference	S	0	D	Risk	Recommend-		Post	Risl	
No.	Function	Failure Mode (Failure Mode)	Failure (Effect)	Mechanism of Failure						Priority Number (S*O*D)	ended Actions (if any)	S	0		RPN S*O*D
3.	Component preparation	Failure of Component preparation and sterilization.	Improper cleaning and sterilization of component leads to contamination in product.	 Due to lack of unqualified sterilizer. Lack of component cleaning and component sterilization procedure. Steam lack or utility cut off during sterilization phase. Articles cleaning and sterilization by untrained person. Load pattern may not follow. Selection of wrong recipe. Sensor malfunctioning. Due to sterilization, material hold time cross 	 Qualification of sterilizer has been completed. Component cleaning and sterilization SOP is in place. If the steam lack occurs during sterilization phase, alarm will generate and same shall be acknowledged by operator and cycle will be considered as abort. Training has been imparted to all concerned persons. Validated load patterns should be refers before start of activity as per respective SOP. Validated recipe and parameter has been set in autoclave PLC and controlled through password. Defined frequency in place for schedule calibration, Preventive maintenance and validation status. Sterilized hold time has been established and actual material hold time is track in BMR. 	Operation and Cleaning of Autoclave Cum Bung Processer	3	2		6	NA.	NA	NA	NA	NA



QUALITY ASSURANCE DEPARTMENT

QUALITY RISK ASSESSEMENT AND MITIGATION PLAN

QRA No.:

Name of Facility/Equipment/Utility/System/Activity/Procedure

Unit Operation: Description: The objective of the risk assessment is to evaluate the risk associated during the Date of Quality Risk Assessment:

Sr. No.	Item/ Function	Potential Failure Mode	Potential Effect of Failure	Potential Cause/ Mechanism of Failure	Current Control	Reference	S	0	D	Risk Priority	Recommend- ended		Post	Risk	RPN
		(Failure Mode)	(Effect)							Number (S*O*D)	Actions (if any)	S	0		S*O*D
4.	During Filter Integrity testing	Failure in filter integrity	Improper filter integrity gets direct impact on sterility of product.	 Unqualified equipment used. Lack of cleaning and operational SOP. Filter integrity activity performed by untrained person. No cross checks provision for filter integrity test report. 	 Qualification of filter integrity machine has been completed. Cleaning and Operational SOP is in place Training has been imparted to all concerned persons and user ID given after completion of training. Filter integrity test report (Pre and Post) shall be checked by production person and verified by QA person. 	Operation of Integrity Tester	5	1	1	5	NA	NA	NA	NA	NA



QUALITY ASSURANCE DEPARTMENT

QUALITY RISK ASSESSEMENT AND MITIGATION PLAN

QRA No.:

Name of Facility/Equipment/Utility/System/Activity/Procedure

Unit Operation: Description: The objective of the risk assessment is to evaluate the risk associated during the Date of Quality Risk Assessment:

Sr.	Item/	Potential	Potential Effect of	Potential Cause/	Current Control	Reference	S	0	D	Risk	Recommend-		Post	Risł	
No.	Function	Failure Mode (Failure Mode)	Failure (Effect)	Mechanism of Failure						Priority Number (S*O*D)	ended Actions (if any)	S	0	D	RPN S*O*D
5.	During compounding	Failure in Batch manufacturing	 Due to improper manufacturing procedure leads to Bioburden may increase more than specification. Unexpected outcome like yield and concentration of product leads to product failure. 	 Compounding procedure not available. Due to lack of calibration ,preventive maintenance, operational and cleaning procedures. Qualification of vessel system not available. Unsterlized and unclean equipment may use. Inadequate cleaning or equipment's difficult to clean. Compounding activity handle by untrained person. Due to lack of clean equipment hold time may cross. Micro growth due to utility supply such as WFI, Compressed air and nitrogen. 	 Detail, compounding procedure is in place in BMR. Vessel calibration, preventive maintenance, operational and cleaning procedure are in place. Qualification of vessels system is completed. In line clearance of compounding activity ensure the sterilization vessels shall be mention in BMR. Vessels CIP, SIP procedure are qualified and SOP is in place. Training has been completed for all concerned persons. CIP hold time has been established. Water system compressed air and Nitrogen are qualified. 	Load Cell Verification and Calibration of Manufacturing Vessels CIP of Mixing vessel, Mixing mobile vessel, holding vessel	5	3		15	Sample shall be collected for QC analytical and QC microbiologi cal to check the impact of CPP on CQA. CPP and CQA shall be evaluated after completion of process validation activity.	5	1	1	5



QUALITY ASSURANCE DEPARTMENT

QUALITY RISK ASSESSEMENT AND MITIGATION PLAN

QRA No.:

Name of Facility/Equipment/Utility/System/Activity/Procedure

Unit Operation: Description: The objective of the risk assessment is to evaluate the risk associated during the Date of Quality Risk Assessment:

Sr.	Item/	Potential	Potential Effect of	Potential Cause/	Current Control	Reference	S	0	D	Risk	Recommend-		Post	Ris	K
No.	Function	Failure Mode (Failure Mode)	Failure (Effect)	Mechanism of Failure						Priority Number (S*O*D)	ended Actions (if any)	S	0	D	RPN S*O*D
6.	Filtration activity	Failure in filtration of bulk solution	 Filtrate is not sterile leads to microbial growth. Improper filtration leads to contamination in product. 	 Lack of procedure for sterilization of filter. Lack of procedure to check the filter integrity. Due to improper training to concerned persons. Lack of filtration procedures. 	 SOP is in place for SIP of vessel system along with product transfer line. Filter integrity procedure is in place check points is available. Training procedures is in place. Filtration procedure is available in BMR. 	SIP for Mixing Vessel/ MMV/ Holding Vessel/Buffer Vessel	5	3	1	15	Sample shall be collected for QC analytical and QC microbiologi cal to check the effect of filtration.	5	1	1	5



QUALITY ASSURANCE DEPARTMENT

QUALITY RISK ASSESSEMENT AND MITIGATION PLAN

QRA No.:

Name of Facility/Equipment/Utility/System/Activity/Procedure

Unit Operation: Description: The objective of the risk assessment is to evaluate the risk associated during the Date of Quality Risk Assessment:

Sr.	Item/	Potential	Potential Effect of	Potential Cause/	Current Control	Reference	S	0	D	Risk	Recommend-		Pos	t Risl	ĸ
No.	Function	Failure Mode (Failure Mode)	Failure (Effect)	Mechanism of Failure						Priority Number (S*O*D)	ended Actions (if any)	s	0	D	RP S*O
7.	Bulk Hold	Failure in Bulk Hold	During bulk solution hold period Bioburden may increase more than the specification.	connection.	 Qualification of the vessel system has been completed. Aseptic connection for filtration is defined in BMR. The vessel is closed system and operated through control HMI. The vessel kept under positive pressure during bulk hold which does not allow the infiltration of microbial contaminants. The procedure is in place filter integrity for vent filter. Magnehelic guage is there for monitoring the pressure Training procedure is in place for operation of the vessel. 	Handling of Filters	4	3	2	24	Product hold time shall be establish during process validation batches	5	1	1	5



QUALITY ASSURANCE DEPARTMENT

QUALITY RISK ASSESSEMENT AND MITIGATION PLAN

QRA No.:

Name of Facility/Equipment/Utility/System/Activity/Procedure

Unit Operation: Description: The objective of the risk assessment is to evaluate the risk associated during the Date of Quality Risk Assessment:

Sr.	Item/	Potential	Potential Effect of	Potential Cause/	Current Control	Reference	S	0	D	Risk	Recommend-		Post	Risł	2
No.	Function	Failure Mode (Failure Mode)	Failure (Effect)	Mechanism of Failure						Priority Number (S*O*D)	ended Actions (if any)	S	0		RPN S*O*I
8.	Ampoule washing	Failure in Ampoule washing	 Improper Ampoule washing procedure leads to contamination Due improper cleaning particulate matter may presence in Ampoules and leads to failure in visual inspection. 	 Lack of qualified equipment. Lack of operational procedure. Due to activity handled by untrained person. Due to lack of cleaning operation and preventive maintenance procedure. Due to improper utility supply. 	 Qualification has been completed for Ampoule washing machine. Operational SOP is in place. Training has been imparted to concerned persons. A cleaning, operational and preventive maintenance procedure is in place. SOP is in place for parameter of utility supply. 	Operation and Cleaning of Ampoule Washing Machine	5			5	NA	NA	NA	NA	NA



QUALITY ASSURANCE DEPARTMENT

QUALITY RISK ASSESSEMENT AND MITIGATION PLAN

QRA No.:

Name of Facility/Equipment/Utility/System/Activity/Procedure

Unit Operation: Description: The objective of the risk assessment is to evaluate the risk associated during the Date of Quality Risk Assessment:

Sr.	Item/	Potential	Potential Effect of	Potential Cause/	Current Control	Reference	S	0	D	Risk	Recommend-		Post	Ris	κ.
No.	Function	Failure Mode (Failure Mode)	Failure (Effect)	Mechanism of Failure						Priority Number (S*O*D)	ended Actions (if any)	s	0		RPN S*O*E
9.	Tunnel operation	Failure in Ampoules depyrogenation.	 Improper depyrogenation leads BET and Sterility Failure. Failure in tunnel leads to loss of time and resources. 	 Unqualified equipment may use. Lack of cleaning and operational procedure. Untrained person may operate machine Tunnel temperature and DP fluctuation during batch activity Selection of wrong parameters and recipe Sensor malfunctioning. 	 Qualification has been completed for tunnel. Operational SOP is in place. Training has been imparted to concerned persons. Cleaning SOP is in place. Tunnel conveyer belt will stop automatically if sensor temperature goes out of set point. The intervention has been performed in media fill batch. Defined frequency is in place for schedule calibration, temperature sensor, Preventive maintenance and validation status of tunnel sterilizer. Validated recipe and parameter is in place. 	Operation of Cleaning of Sterilizing & Depyrogenation Tunnel	5	1	1	5	NA	NA	NA	NA	NA



QUALITY ASSURANCE DEPARTMENT

QUALITY RISK ASSESSEMENT AND MITIGATION PLAN

QRA No.:

Name of Facility/Equipment/Utility/System/Activity/Procedure

Unit Operation: Description: The objective of the risk assessment is to evaluate the risk associated during the Date of Quality Risk Assessment:

Sr.	Item/	Potential	Potential Effect of	Potential Cause/	Current Control	Reference	S	0	D	Risk	Recommend-		Post	Risl	<u> </u>
No.	Function	Failure Mode (Failure Mode)	Failure (Effect)	Mechanism of Failure						Priority Number (S*O*D)	ended Actions (if any)	S	0	D	RPN S*O*D
10.	Filling operation	Failure in filling and Sealing.	 Improper filling may result in volume variation. Improper filling and Sealing activity may leads to contamination. 	 Lack of qualification procedure. Lack of cleaning and operational procedure. Unsterile parts or article may use I filling operation. Lack of environmental condition for filling. Improper handling of aseptic intervention may lead to product contamination. Operation handled by untrained and unqualified person. Due aseptic interventions Due filling duration. 	 Qualification of filling and stoppering machine has been completed. SOP for filling machine cleaning and operation is in place. Sterilization procedure for machine parts loads is in place. Filling shall be carried out under class A condition(Unidirectional air flow area) Aseptic intervention shall be performed as per media fill protocol and BMR. Operational training has been done for all concerned persons for aseptic. Filling duration is mentioned in BMR and same was simulated in media fill. 	Operation and Cleaning of Automatic High Speed Injectable Ampoule Filling and Sealing Machine	5	2	2	20	If in case any unexpected intervention will happen during batch processing same shall be documented and handled through QMS.	5	1		5



QUALITY ASSURANCE DEPARTMENT

QUALITY RISK ASSESSEMENT AND MITIGATION PLAN

QRA No.:

Name of Facility/Equipment/Utility/System/Activity/Procedure

Unit Operation: Description: The objective of the risk assessment is to evaluate the risk associated during the Date of Quality Risk Assessment:

Sr.	Item/	Potential	Potential Effect of	Potential Cause/	Current Control	Reference	S	0	D	Risk	Recommend-		Post	Risl	
No.	Function	Failure Mode (Failure Mode)	Failure (Effect)	Mechanism of Failure						Priority Number (S*O*D)	ended Actions (if any)	S	0	D	RPN S*O*]
11.	Sealing operation	Failure in Ampoule sealing	 Improper Sealing is not providing leak proof sealing to the Ampoules. Failure in sealing activity leads to product contamination. 	may not available.	 Qualification for Ampoule filling and sealing machine has been completed. Operational and cleaning SOP is in place. Training has imparted to concerned persons. SOP is in place for leak test for sealed Ampoule. 	Operation and Cleaning of Automatic High Speed Injectable Ampoule Filling and Sealing Machine	5	1	1	5	NA	NA	NA	NA	NA



QUALITY ASSURANCE DEPARTMENT

QUALITY RISK ASSESSEMENT AND MITIGATION PLAN

QRA No.:

Name of Facility/Equipment/Utility/System/Activity/Procedure

Unit Operation: Description: The objective of the risk assessment is to evaluate the risk associated during the Date of Quality Risk Assessment:

Sr.	Item/	Potential	Potential Effect of	Potential Cause/	Current Control	Reference	S	0	D	Risk	Recommend-		Post	Ris	k
No.	Function	Failure Mode (Failure Mode)	Failure (Effect)	Mechanism of Failure						Priority Number (S*O*D)	ended Actions (if any)	S	0	D	RPN S*O*D
12.	Visual Inspection	Failure in visual inspection	 Improper visual inspection of Ampoules leads to direct impact on product quality and patient safety. Improper visual inspection to Ampoules gets market complaints to the organization. 	 Lack of qualification procedure for visual inspector. Lack of SOP for visual inspection procedure. Visual inspection activity done by unqualified person. Lack of cross check procedure for inspected Ampoule. Visual inspection hood not qualified. Lack of required lux level. 	 Qualification for Automatic optical inspection machine has been completed Visual inspector qualification procedure is in place. SOP is in place for Automatic optical inspection activity. Inprocess checks is in place for visual inspection activity and AQL is in place. 	Operation Cleaning of Automatic Visual Inspection Machine	3	1	5	15	NA	1	1	5	5



QUALITY ASSURANCE DEPARTMENT

QUALITY RISK ASSESSEMENT AND MITIGATION PLAN

QRA No.:

Name of Facility/Equipment/Utility/System/Activity/Procedure

Unit Operation: Description: The objective of the risk assessment is to evaluate the risk associated during the Date of Quality Risk Assessment:

Sr.	Item/	Potential	Potential Effect of	Potential Cause/	Current Control	Reference	S	0	D	Risk	Recommend-		Post	Ris	ĸ
No.	Function	Failure Mode (Failure Mode)	Failure (Effect)	Mechanism of Failure						Priority Number (S*O*D)	ended Actions (if any)	S	0	D	RPN S*O*D
13.	Storage condition in FG	Improper storage space and conditions in Finished goods store.	 Chance of product mix-up due to lack of dedicated space. Chance of product degradation due to irrespective storage condition. 	 Lack of SOP Lack of dedicated storage space Due to environmental condition not maintain. 	 SOP for handling of finished good is in place. Dedicated storage space is available. Environmental condition is monitoring through BMS. 	Handling Of Finished Goods	1	1	5	5	NA	NA	NA	NA	NA
14.	Labeling Activity	Improper Labeling in Product.	Improper labeling leads to adverse effect on patient health.	 Lack of SOP of Labeling machine Lack of Line clearance and physical verification. Lack of proper Dispensing of Packing material. 	 SOP of labeling machine is in place. Training imparted to IPQA person for Line clearance and proof check. SOP of Packing material Dispensing is in place. 	Dispensing and Issuance of Packing Material	1	1	5	5	NA	NA	NA	NA	NA



QUALITY ASSURANCE DEPARTMENT

QUALITY RISK ASSESSEMENT AND MITIGATION PLAN

QRA No.:

Name of Facility/Equipment/Utility/System/Activity/Procedure

Unit Operation: Description: The objective of the risk assessment is to evaluate the risk associated during the Date of Quality Risk Assessment:

Process Validation Batch of Tranexamic Acid Injection BP 5 ml

Sr.	Item/	Potential	Potential Effect of	Potential Cause/	Current Control	Reference	S	0	D	Risk	Recommend-		Post	Risł	K
No.	Function	Failure Mode (Failure Mode)	Failure (Effect)	Mechanism of Failure						Priority Number (S*O*D)	ended Actions (if any)	S	0	D	RPN S*O*D
15.	Secondary Packing activity	Improper packing of the product.	 Improper packing leads to product damage. Wrong packing leads to risk on patient safety. 	 Lack of SOP of carton packing Lack of Line clearance and physical verification. Lack of proper Dispensing of Packing material. 	 SOP of operation and cleaning of Hi-cart carton packing machine is in place. Training imparted to IPQA person for Line clearance and proof check. SOP of Packing material Dispensing is in place. 	Operation and Cleaning of Hi- cart Cartoning Machine	1	1	5	5	NA	NA	NA	NA	NA

Where: S=Severity; O=Occurrence Probability; D=Detection; Risk category 1-25 RPN is Low risk, 26-50 RPN is Medium Risk, 51-125 RPN is High Risk.

	y/Equipment/Utility/System/Activity/Procedure/Unit Operation: tion For Liquid Injection	Date: NA					
S. No.	Recommended Action	Responsible Person	Target Date of Completion				
1.							
2.							



QUALITY ASSURANCE DEPARTMENT

QUALITY RISK ASSESSEMENT AND MITIGATION PLAN

	QUAI	IIII KISK AS	SESSEMENT AND MI	IIGATION FLAN			
)RA No.:							
Name of Facility/Equipment/Uti Unit Operation: Description: Th Process Validation Batch of Trane	e objective of the risk assess	Date of Quality Risk Assessment:					
APA: required, mention CAPA No.:							
	Quality Risk Manageme	ent Team		Reviewed By	Approved By		
Name	Departme	ent	Sign & Date	Head Operations Sign & Date	Head QA Sign & Date		
				_			
	QUA	LITY RISK ASSES	SEMENT AND MITIGATION	SUMMARY REPORT			
Name of Facility/Equipment/Utility/	/System/Activity/Procedure:	Process Validation	on Batch of Tranexamic Acid	Injection BP 5 ml			
erification of Action Plan: NA emarks (if any): The entire above fai	lure mode and their Severity, Oco	currence, Detection r	ating done and RPN No. is found	between 1-25. Hence Risk is detected as low wh	nich is acceptable.		
Verified By QA Sign & Date				Approved Head Q Sign & D	A		